



A.B.M.S. Parishad's
YASHWANTRAO CHAVAN LAW COLLEGE,
PARVATI, PUNE – 411009

ID No. PU/PN/LAW/038/1978, Affiliated to Savitribai Phule Pune University, Recognized by
BCI and Accredited by NAAC, Bengaluru

Website- www.yclawcollegepune.org, Email- yclawpune@gmail.com, Telephone- 020-24221002



SSR 2023 for Cycle IV
2017-18 to 2021-2022

Criterion 7 – Institutional Values and Best Practices

Key Indicator – 7.1 Institutional Values and Social Responsibilities

7.1.6 Quality audits on environment and energy regularly undertaken by the Institution.



A.B.M.S. Parishad's
YASHWANTRAO CHAVAN LAW COLLEGE,
PARVATI, PUNE – 411009

ID No. PU/PN/LAW/038/1978, Affiliated to Savitribai Phule Pune University, Recognized by
BCI and Accredited by NAAC, Bengaluru

Website- www.yclawcollegepune.org, Email- yclawpune@gmail.com, Telephone- 020-24221002

SSR 2023 for Cycle IV
2017-18 to 2021-2022

Criterion 7 – Institutional Values and Best Practices

Key Indicator – 7.1 Institutional Values and Social Responsibilities

7.1.6 Quality audits on environment and energy regularly undertaken by the Institution.

Table of Contents

| Sr. No | Content | Page No. |
|---------------|---------------------------|-----------------|
| 1 | Green & Energy Audit | 3-46 |
| 2 | Green & Environment audit | 47-101 |
| 3 | Environment Audit | 107-115 |
| 4 | Energy Audit | 116-148 |
| 5 | Green Audit | 149-171 |



CERTIFICATE

ENERFUTURE TECHNOLOGY PRIVATE LIMITED

Verified and Certified that



A.B.M.S PARISHAD'S

YASHWANTRAO CHAVAN LAW COLLEGE

LAXMI NAGAR, PARVATI RAMANA,

PUNE, MAHARASHTRA 411009

PHONE NO: 020 2422 1002

E-mail Id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

HAS CARRIED OUT

GREEN (ENVIRONMENT) AUDIT

AS PER GUIDANCE LAID DOWN IN THE

INDIAN STANDARDS AND CODES

IN 2021-22

This certificate is valid for 3 years from 2021-22 to 2023-24

Vinay Mulay

Vinay Mulay

M.Tech (Energy Studies),

Certified BEE Energy Auditor

(EA-10853), Lead Auditor-ISO-50001

Chetan Nemade

Chetan Nemade

M.Tech (Energy Studies), Advance

Diploma

in Industrial Safety (ADIS),

BEE Certified Energy Manager (EA-22697)

Yogesh Kuwar

Yogesh Kuwar

M.Tech (Energy Studies),

Certified BEE Energy


Manager (EA-33078),

PGDLP, IGBCTM AP-

AA02EEK7



www.ienerfuture.com



CERTIFICATE

ENERFUTURE TECHNOLOGY PRIVATE LIMITED

Verified and Certified that



A.B.M.S PARISHAD'S

YASHWANTRAO CHAVAN LAW COLLEGE

LAXMI NAGAR, PARVATI RAMANA,

PUNE, MAHARASHTRA 411009

PHONE NO: 020 2422 1002

E-mail id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

HAS CARRIED OUT

ENERGY AUDIT


AS PER GUIDANCE LAID DOWN IN THE

ENERGY CONSERVATION ACT-2001,

MINISTRY OF POWER, GOVERNMENT OF INDIA

IN 2021-22

This certificate is valid for 3 years from 2021-22 to 2023-24




Vinay Mulay

M.Tech (Energy Studies),

Certified BEE Energy Auditor

(EA-10853), Lead Auditor-ISO-50001



Chetan Nemade

M.Tech (Energy Studies), Advance

Diploma

in Industrial Safety (ADIS),

BEE Certified Energy Manager (EA-22697)



Yogesh Kuwar

M.Tech (Energy Studies),

Certified BEE Energy

Manager (EA-33078),

PGDELP, IGBCTM AP-

AA02EEK7



PRINCIPAL

**Yashwantrao Chavan Law College
Pune-411 009**



CERTIFICATE

ENERFUTURE TECHNOLOGY PRIVATE LIMITED
Verified and Certified that



A.B.M.S PARISHAD'S

YASHWANTRAO CHAVAN LAW COLLEGE


LAXMI NAGAR, PARVATI RAMANA,
PUNE, MAHARASHTRA 411009
PHONE NO: 020 2422 1002
E-mail Id: yclawcollege@gmail.com
Website: www.yclawcollegepune.org

HAS CARRIED OUT
ENERGY AUDIT
AS PER GUIDANCE LAID DOWN IN THE
ENERGY CONSERVATION ACT-2001,
MINISTRY OF POWER, GOVERNMENT OF INDIA
IN 2021-22

This certificate is valid for 3 years from 2021-22 to 2023-24



Vinay Mulay
M.Tech (Energy Studies),
Certified BEE Energy Auditor
(EA-10853), Lead Auditor-ISO-50001



Chetan Nemade
M.Tech (Energy Studies), Advance
Diploma
in Industrial Safety (ADIS),
BEE Certified Energy Manager (EA-22697)



Yogesh Kuwar
M.Tech (Energy Studies),
Certified BEE Energy
Manager (EA-33078),
PGDELP, IGBCTM AP-
AA02EEK7



www.enerfuture.com

ENERGY AUDIT REPORT



**A.B.M.S PARISHAD'S
YASHWANTRAO CHAVAN LAW COLLEGE**

Laxmi Nagar, Parvati Ramana,

Pune, Maharashtra 411009

Phone No: 020 2422 1002

E-mail Id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

Conducted and Submitted by



ENERFUTURE TECHNOLOGY PRIVATE LIMITED

301, Above Ekbote Hospital,

Revenue Colony, J.M.Road,

Pune-411005

Website: <http://www.enerfutureindia.com/utureindia.com>

E-mail: info@enerfutureindia.com

Telephone: +91- 9960041642, 9405065597

ACKNOWLEDGEMENT

Enerfuture thanks the management of Yashwantrao Chavan Law College, Pune for assigning this important work of Environment Audit of Yashwantrao Chavan Law College, Pune

Environment Audit study is a joint venture exercise of consultant and college/industry/residential society to account and contain energy usage without sacrificing the purpose of energy use.

Contribution of society's team is equally important in this venture. Team of technical experts from Enerfuture Pvt Ltd is grateful to all the following personnel of Yashwantrao Chavan Law College, Pune for their kind cooperation, furnishing required data, analysis report and hospitality offered during our visit.

| Name | Designation |
|-----------------------------|-----------------------|
| Ms Dr Subhada Gholap | Principal |
| Mr. Pramod Phadtare | Office Superintendent |
| Mr Ravindra Patil | Assistant professor |

We are also thankful to the other staff members who were actively involved while taking measurements and conducting field study.

STUDY TEAM

| Sr No | Name | Qualification |
|-------|--------------------|---|
| 1 | Mr. Chetan Nemade | M.Tech (Energy Studies), Advance Diploma in Industrial Safety (ADIS), LLB, BEE Certified Energy Manager |
| 2 | Mr Vinay Mulay | M.Tech (Energy Studies), ISO 50001 Lead Auditor, BEE Accredited Energy Auditor |
| 3 | Mr Swapnil Gaikwad | M.Tech (Energy Studies), ISO 50001 Lead Auditor , BEE Certified Energy Auditor |
| 4 | Mr Yogesh Kuwar | M.Tech (Energy Studies), IGBC, Post Graduate Diploma in Environmental law and Policy (PGDELP), BEE Certified Energy Manager |
| 5 | Mr Swapnil bedre | BE Mechanical |

LIST OF INSTRUMENTS USED

1. Single Phase Power Analyzer
2. Ultrasonic Water Flow meter
3. Distance Meter (Bosch)
4. Lux meter (Meco)
5. TD meter
6. CO2 meter
7. Air quality measure meter
8. Sound meter

CONTENTS

| | |
|---|----|
| EXECUTIVE SUMMARY..... | 7 |
| COLLEGE INTRODUCTION | 9 |
| INTRODUCTION | 9 |
| Vision | 10 |
| Mission..... | 10 |
| Location | 10 |
| ELECTRICITY BILL SUMMARY..... | 11 |
| ELECTRICITY BILL SUMMARY | 11 |
| OBSERVATION | 13 |
| ENERGY PERFORMANCE ASSESSMENT OF LIGHTING..... | 14 |
| COLLEGE BUILDING AND OTHERS | 14 |
| OBSERVATION | 14 |
| PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM | 15 |
| ENERGY SAVING MEASURES | 20 |
| ENERGY SAVING MEASURES- OTHER RECOMMENDATIONS | 25 |
| ENERGY PERFORMANCE ASSESSMENT OF FAN | 26 |
| COLLEGE BUILDING AND OTHERS | 26 |
| OBSERVATION | 26 |
| ENERGY SAVING MEASURES | 26 |
| RENEWABLE ENERGY SYSTEMS..... | 30 |
| 1. SOLAR PHOTOVOLTAIC SYSTEM- ELECTRICAL ENERGY GENERATION..... | 30 |
| INTRODUCTION..... | 30 |
| OBSERVATION | 31 |
| RECOMMENDATION | 32 |
| SAVINGS MEASURES..... | 32 |

| | |
|---|----|
| SAVINGS DUE TO SOLAR PV SYSTEM INSTALLATION- MAIN COLLEGE BUILDING..... | 32 |
| 2. BIO-GAS PLANT..... | 33 |
| INTRODUCTION | 33 |
| OBSERVATION | 35 |
| RECOMMENDATION | 35 |
| SAVINGS..... | 35 |
| ENERGY CONSERVATION BY SAVING OF WATER | 36 |
| TAP WATER REDUCER..... | 36 |
| RECOMMENDATION | 36 |
| ANNEXTURE | 37 |
| ENERGY EFFICIENT FANS..... | 37 |
| ENERGY EFFICIENT LIGHTING..... | 38 |
| ENERGY EFFICIENT INVERTER AC | 39 |

EXCECUTIVE SUMMARY

| Sr no | Location | Area | Proposed Action | Expected Result | Saving Potential | Monetary Saving | Investment | Simple Payback Period |
|-------|--------------------------------|---------------------------|--|---------------------------------------|------------------|-----------------|------------|-----------------------|
| | | | | | monthly | kWh | INR | INR |
| 1 | College building | Lightning recommendations | Replace existing old conventional 1x36W with new energy efficient 1x18W LED tube light battens | Existing lighting consumption=1500kWh | 540 | 6480 | 30000 | 4.93 |
| | College building | Fan recommendations | | Expected energy consumption= 960kWh | | | | |
| | | | Total energy saved per month=540kWh | Expected energy consumption= 1125kWh | | | | |
| 3 | Available rooftop on buildings | Solar PV system | Can be installed 74kWp system | - | 2484 | 29810 | 993681 | 33.33 |

| | | | | | | | | |
|---|-----------------|---------------|---|--|----------------|-----|-------|-------|
| 4 | College canteen | Bio-gas plant | Installed the 10 kg of bio-gas plant at canteen to save LPG cylinders | | 1 LPG cylinder | 950 | 25000 | 26.31 |
|---|-----------------|---------------|---|--|----------------|-----|-------|-------|

COLLEGE INTRODUCTION

INTRODUCTION



Our Yashwantrao Chavan Law College was established in June 1978. In the beginning, the college was known as A. B. M. S. Parishad' s Law college. However, in the year 1987, in the memory of our country's great visionary leader, Late Shri Yashwantrao Chavan, who rose to the height of Deputy of Prime Minister, the college was named after him, as a mark of respect and honour towards him. The college has been receiving grant-in-aid from the state government. It has received the re-accreditation from NAAC. Our college is affiliated to Savitribai Phule Pune University on permanent basis and also recognized the Bar Council of India, New Delhi.

The College has its own spacious building which is located in the same campus of A B M S Parishad and which has been constructed as per the norms laid down the UGC. The building was inaugurated on 20th February, 2005 at the auspicious hands of Honorable Shri Sharadrao Pawar (Former Agriculture Minister, Government of India and the President of A B M S Parishad) in presence of Mr. Ajit Pawar (Deputy Chief Minister, Govt. of Maharashtra).

The college has kept before itself the goals of advancement and dissemination of knowledge of law and legal process in the context of national development. In accordance with these basic expectations, the college is striving to achieve excellence in the field of legal education and research. While imparting legal education, the college has kept a goal in view that the professional lawyers must be well equipped to perform the various roles which they are expected to in our society. The college has completed its forty two years. Over the years, it has created a niche in the field of law education in the city. As everybody is aware, Pune city being the seat of learning and education, students from all over Maharashtra, particularly from rural area, and from the other states as well rush to this great city in search of homely atmosphere, where education is imparted to them. It is the vision of our Society and its various institutions to get these students into their fold and groom them for their professional excellence in various fields.

Our college thus provides not only professional excellence in the field of law education but also makes the rural students worthy of entering into the professional field. We make an excellent combination of the state-of-the art education as well as the deep rooted educational culture. Over the years, we have produced thousands of lawyers, who have gone back to their villages and tahsils for serving the society and running the profession successfully. Some of them have also joined as government services and the private sector. This is how our college is fulfilling its commitment of the noble mission.

Vision

“Pioneering a high quality legal education and inculcating social, cultural and ethical values in students to emerge as socially good, professionally sound and competent citizens”

Mission

1. To bridge the gap between theoretical knowledge and professional practice.
2. To create the free spirit among the students to serve the interests of justice.
3. To mould students with varied interests, talent and experience into competent, independent and ethical legal professionals.
4. To impart standard legal education to students to have an enduring advantage to confront the challenge of the rapidly changing world.
5. To promote a high level of learning and research ability through interactive education and continuous assessment of academic performance of student.

Location



ELECTRICITY BILL SUMMARY

Yashwantrao Chavan Law College has one MSEDCL three phase LT electricity connection in the main college building and other two have in boy's hostel and girl's hostel.

The major electricity consumption in main college building is lighting and fans during college hours. In boy's and girl's hostel lighting, fans and water pump are main electricity consuming utilities.

ELECTRICITY BILL SUMMARY

1. ELECTRICITY BILL SUMMARY

| | | | | |
|-----------------------|---|-----------------------|-------------------|--------------------------|
| Meter No | 160240191081 | | | |
| BU | 4605 | | | |
| Connected load | 15 | | | kW |
| Meter | LT-X-B-I, 0-20kW Pub Sector others 3-phase | | | |
| | Total units | Adjusted units | Total Bill | Average Unit Rate |
| | kWh | kWh | INR/month | INR/kWh |
| Feb-21 | 1044 | 0 | 10033.01 | 9.61 |
| Mar-21 | 1289 | 0 | 13126.92 | 10.18 |
| Apr-21 | 1223 | 0 | 13037.18 | 10.66 |
| May-21 | 0 | 0 | 350 | 0.00 |
| Jun-21 | 0 | 0 | 350 | 0.00 |
| Jul-21 | 3785 | 1957 | 20230.19 | 5.34 |
| Aug-21 | 668 | 291 | 2812.23 | 4.21 |
| Sep-21 | 640 | 1 | 432.12 | 0.68 |
| Oct-21 | 541 | 0 | 350 | 0.65 |
| Nov-21 | 770 | 257 | | 0.00 |
| Dec-21 | 493 | 197 | 1835.23 | 3.72 |
| Jan-22 | 836 | 207 | 6045.52 | 7.23 |

| | | | |
|-----------------------|---|-------------------|--------------------------|
| Meter No | 170012480744 | | |
| BU | 4605 | | |
| Connected load | 1 | kW | |
| Meter | LT-X-B-I, 0-20kW Pub Sector others 3-phase | | |
| | Total units | Total Bill | Average Unit Rate |
| | kWh | INR/month | INR/kWh |
| Feb-21 | 480 | 6049 | 12.60 |
| Mar-21 | 472 | 5769 | 12.22 |
| Apr-21 | 446 | 5417 | 12.15 |
| May-21 | 512 | 6270 | 12.25 |
| Jun-21 | 479 | 5866 | 12.25 |
| Jul-21 | 431 | 5167 | 11.99 |
| Aug-21 | 368 | 4309 | 11.71 |
| Sep-21 | 441 | 5349 | 12.13 |
| Oct-21 | 809 | 10813 | 13.37 |
| Nov-21 | 798 | 10715 | 13.43 |
| Dec-21 | 1570 | 22465 | 14.31 |
| Jan-22 | 1028 | 14166 | 13.78 |

| | | | |
|-----------------------|---|-------------------|--------------------------|
| Meter No | 160240583884 | | |
| BU | 4605 | | |
| Connected load | 25 | kW | |
| Meter | LT-X-B-I, 0-20kW Pub Sector others 3-phase | | |
| | Total units | Total Bill | Average Unit Rate |
| | kWh | INR/month | INR/kWh |
| Feb-21 | 1023 | 8061.24 | 7.88 |
| Mar-21 | 440 | 3273.6 | 7.44 |
| Apr-21 | 2603 | 18923.81 | 7.27 |
| May-21 | 2097 | 15706.53 | 7.49 |
| Jun-21 | 1767 | 13976.97 | 7.91 |
| Jul-21 | 2535 | 19925.1 | 7.86 |
| Aug-21 | 939 | 6976.77 | 7.43 |
| Sep-21 | 3184 | 24357.6 | 7.65 |
| Oct-21 | 1415 | 10541.75 | 7.45 |
| Nov-21 | 2270 | 16412.1 | 7.23 |
| Dec-21 | 1997 | 15476.75 | 7.75 |
| Jan-22 | 987 | 7880 | 7.98 |

OBSERVATION

1. Total monthly energy consumption of the college is approximate 3365 units.
2. Total monthly billing is INR 28,260/-
3. Solar water heating system is installed in hostel for hot water generation as renewable energy source.
4. Also solar photovoltaic system is installed at college building for electricity generation as a renewable energy resource.


ENERGY PERFORMANCE ASSESSMENT OF LIGHTING

COLLEGE BUILDING AND OTHERS

OBSERVATION

College has installed new energy efficient LED lighting in the college building. There are old conventional lightings are also in the college in use.

| Type | Quantity | kW load | % of load |
|---------------------------|-------------|--------------|------------|
| LED lighting | 1372 | 24.70 | 47.42 |
| Old conventional lighting | 1521 | 54.76 | 52.58 |
| Total | 2893 | 79.45 | 100 |



PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM

| Building | Floor | Light Type | Type | Qty | Wattage | Hours of usage | No of Days in a month | Monthly consumption |
|---------------|--------------|------------|-------|-----|---------|----------------|-----------------------|---------------------|
| | | | | Nos | watt | hrs | days | kWh/day |
| Main building | Ground floor | LED | 1x18W | 12 | 18 | 5 | 25 | 27.00 |
| | | FTL | 1x36W | 40 | 36 | 5 | 25 | 180.00 |
| | | LED | 1x18W | 28 | 18 | 5 | 25 | 63.00 |
| | | FTL | 1x36W | 3 | 36 | 5 | 25 | 13.50 |
| | | LED | 1x18W | 15 | 18 | 5 | 25 | 33.75 |
| | | LED | 1x18W | 1 | 18 | 5 | 25 | 2.25 |
| | | LED | 1x18W | 8 | 18 | 5 | 25 | 18.00 |
| | | LED | 1x18W | 38 | 18 | 5 | 25 | 85.50 |
| | | LED | 1x18W | 3 | 18 | 5 | 25 | 6.75 |
| | | FTL | 1x36W | 61 | 36 | 5 | 25 | 274.50 |
| | LED | 1x18W | 22 | 18 | 5 | 25 | 49.50 | |
| | FTL | 1x36W | 16 | 36 | 5 | 25 | 72.00 | |
| | LED | 1x18W | 38 | 18 | 5 | 25 | 85.50 | |
| | FTL | 1x36W | 4 | 36 | 5 | 25 | 18.00 | |
| | LED | 1x9W | 25 | 9 | 5 | 25 | 28.13 | |
| | LED | 1x18W | 13 | 18 | 5 | 25 | 29.25 | |
| | FTL | 1x36W | 20 | 36 | 5 | 25 | 90.00 | |
| | FTL | 1x18W | 44 | 18 | 5 | 25 | 99.00 | |
| | FTL | 1x36W | 36 | 36 | 5 | 25 | 162.00 | |
| | LED | 1x50W | 24 | 18 | 5 | 25 | 54.00 | |
| | | FTL | 1x36W | 50 | 36 | 5 | 25 | 225.00 |
| | First floor | FTL | 1x36W | 40 | 36 | 5 | 25 | 180.00 |

| | | | | | | | | |
|-----------------|--------------|-----|-------|-----|----|---|----|--------|
| | | FTL | 1x36W | 34 | 36 | 5 | 25 | 153.00 |
| | | FTL | 1x36W | 7 | 36 | 5 | 25 | 31.50 |
| | | FTL | 1x36W | 31 | 36 | 5 | 25 | 139.50 |
| | | FTL | 1x36W | 84 | 36 | 5 | 25 | 378.00 |
| | | FTL | 1x36W | 51 | 36 | 5 | 25 | 229.50 |
| | | LED | 1x18W | 2 | 18 | 5 | 25 | 4.50 |
| | | FTL | 1x36W | 32 | 36 | 5 | 25 | 144.00 |
| | | LED | 1x18W | 50 | 18 | 5 | 25 | 112.50 |
| | | FTL | 1x36W | 99 | 36 | 5 | 25 | 445.50 |
| | | LED | 1x18W | 32 | 18 | 5 | 25 | 72.00 |
| | | LED | 1x18W | 48 | 18 | 5 | 25 | 108.00 |
| | Second floor | LED | 1x18W | 5 | 18 | 5 | 5 | 2.25 |
| | | FTL | 1x36W | 18 | 36 | 5 | 25 | 81.00 |
| | | FTL | 1x36W | 43 | 36 | 5 | 25 | 193.50 |
| | | FTL | 1x36W | 19 | 36 | 5 | 25 | 85.50 |
| | | FTL | 1x36W | 25 | 36 | 5 | 25 | 112.50 |
| | | LED | 1x18W | 45 | 18 | 5 | 25 | 101.25 |
| | | LED | 1x18W | 86 | 18 | 5 | 25 | 193.50 |
| | | FTL | 1x36W | 9 | 36 | 5 | 25 | 40.50 |
| | | FTL | 1x36W | 20 | 36 | 5 | 25 | 90.00 |
| | Third floor | LED | 1x18W | 9 | 18 | 5 | 25 | 20.25 |
| | | FTL | 1x36W | 82 | 36 | 5 | 25 | 369.00 |
| | | LED | 1x18W | 88 | 18 | 5 | 25 | 198.00 |
| Premises | | LED | 1x18W | 15 | 18 | 5 | 25 | 33.75 |
| | | FTL | 1x36W | 7 | 36 | 5 | 25 | 31.50 |
| | | LED | 1x18W | 47 | 18 | 5 | 25 | 105.75 |
| Hostels | | LED | 1x18W | 150 | 18 | 5 | 25 | 337.50 |

| | | | | | | | |
|--|-----|-------|-----|----|----|------|--------|
| | FTL | 1x36W | 72 | 36 | 5 | 25 | 324.00 |
| | LED | 1x18W | 114 | 18 | 5 | 25 | 256.50 |
| | FTL | 1x36W | 114 | 36 | 5 | 25 | 513.00 |
| | LED | 1x18W | 95 | 18 | 5 | 25 | 213.75 |
| | FTL | 1x36W | 95 | 36 | 5 | 25 | 427.50 |
| | LED | 1x18W | 11 | 18 | 5 | 25 | 24.75 |
| | FTL | 1x36W | 4 | 36 | 5 | 25 | 18.00 |
| | FTL | 1x36W | 2 | 36 | 5 | 25 | 9.00 |
| | LED | 1x18W | 3 | 18 | 10 | 30.5 | 16.47 |
| | FTL | 1x36W | 2 | 36 | 10 | 30.5 | 21.96 |
| | LED | 1x18W | 20 | 18 | 10 | 30.5 | 109.80 |
| | FTL | 1x36W | 20 | 36 | 10 | 30.5 | 219.60 |
| | LED | 1x18W | 4 | 18 | 10 | 30.5 | 21.96 |
| | FTL | 1x36W | 3 | 36 | 10 | 30.5 | 32.94 |
| | LED | 1x18W | 15 | 18 | 10 | 30.5 | 82.35 |
| | FTL | 1x36W | 18 | 36 | 10 | 30.5 | 197.64 |
| | LED | 1x18W | 6 | 18 | 10 | 30.5 | 32.94 |
| | FTL | 1x36W | 6 | 36 | 10 | 30.5 | 65.88 |
| | LED | 1x18W | 2 | 18 | 10 | 30.5 | 10.98 |
| | FTL | 1x36W | 2 | 36 | 10 | 30.5 | 21.96 |
| | LED | 1x18W | 8 | 18 | 10 | 30.5 | 43.92 |
| | FTL | 1x36W | 9 | 36 | 10 | 30.5 | 98.82 |
| | LED | 1x18W | 2 | 18 | 10 | 30.5 | 10.98 |
| | FTL | 1x36W | 2 | 36 | 10 | 30.5 | 21.96 |
| | LED | 1x18W | 1 | 18 | 10 | 30.5 | 5.49 |
| | LED | 1x18W | 22 | 18 | 10 | 30.5 | 120.78 |
| | FTL | 1x36W | 22 | 36 | 10 | 30.5 | 241.56 |

| | | | | | | | |
|--|-----|-------|----|----|----|------|--------|
| | LED | 1x18W | 6 | 18 | 10 | 30.5 | 32.94 |
| | FTL | 1x36W | 7 | 36 | 10 | 30.5 | 76.86 |
| | FTL | 1x36W | 2 | 36 | 10 | 30.5 | 21.96 |
| | LED | 1x18W | 3 | 18 | 10 | 30.5 | 16.47 |
| | FTL | 1x36W | 3 | 36 | 10 | 30.5 | 32.94 |
| | LED | 1x18W | 5 | 18 | 10 | 30.5 | 27.45 |
| | FTL | 1x36W | 4 | 36 | 10 | 30.5 | 43.92 |
| | LED | 1x18W | 4 | 18 | 10 | 30.5 | 21.96 |
| | FTL | 1x36W | 4 | 36 | 10 | 30.5 | 43.92 |
| | LED | 1x18W | 19 | 18 | 10 | 30.5 | 104.31 |
| | FTL | 1x36W | 20 | 36 | 10 | 30.5 | 219.60 |
| | LED | 1x18W | 4 | 18 | 10 | 30.5 | 21.96 |
| | FTL | 1x36W | 4 | 36 | 10 | 30.5 | 43.92 |
| | LED | 1x18W | 8 | 18 | 10 | 30.5 | 43.92 |
| | FTL | 1x36W | 9 | 36 | 10 | 30.5 | 98.82 |
| | LED | 1x18W | 2 | 18 | 10 | 30.5 | 10.98 |
| | FTL | 1x36W | 2 | 36 | 10 | 30.5 | 21.96 |
| | LED | 1x18W | 3 | 18 | 10 | 30.5 | 16.47 |
| | FTL | 1x36W | 4 | 36 | 10 | 30.5 | 43.92 |
| | LED | 1x18W | 3 | 18 | 10 | 30.5 | 16.47 |
| | FTL | 1x36W | 3 | 36 | 10 | 30.5 | 32.94 |
| | LED | 1x18W | 12 | 18 | 10 | 30.5 | 65.88 |
| | FTL | 1x36W | 13 | 36 | 10 | 30.5 | 142.74 |
| | LED | 1x18W | 29 | 18 | 10 | 30.5 | 159.21 |
| | FTL | 1x36W | 29 | 36 | 10 | 30.5 | 318.42 |
| | LED | 1x18W | 23 | 18 | 10 | 30.5 | 126.27 |
| | FTL | 1x36W | 24 | 36 | 10 | 30.5 | 263.52 |

| | | | | | | | |
|--|-----|-------|----|----|----|------|--------|
| | LED | 1x18W | 4 | 18 | 10 | 30.5 | 21.96 |
| | FTL | 1x36W | 5 | 36 | 10 | 30.5 | 54.90 |
| | LED | 1x18W | 27 | 18 | 10 | 30.5 | 148.23 |
| | FTL | 1x36W | 28 | 36 | 10 | 30.5 | 307.44 |
| | LED | 1x18W | 24 | 18 | 10 | 30.5 | 131.76 |
| | FTL | 1x36W | 24 | 36 | 10 | 30.5 | 263.52 |
| | LED | 1x18W | 26 | 18 | 10 | 30.5 | 142.74 |
| | FTL | 1x36W | 26 | 36 | 10 | 30.5 | 285.48 |
| | LED | 1x18W | 15 | 18 | 10 | 30.5 | 82.35 |
| | FTL | 1x36W | 15 | 36 | 10 | 30.5 | 164.70 |
| | LED | 1x18W | 6 | 18 | 10 | 30.5 | 32.94 |
| | FTL | 1x36W | 6 | 36 | 10 | 30.5 | 65.88 |
| | LED | 1x18W | 4 | 18 | 10 | 30.5 | 21.96 |
| | FTL | 1x36W | 4 | 36 | 10 | 30.5 | 43.92 |
| | LED | 1x18W | 21 | 18 | 10 | 30.5 | 115.29 |
| | FTL | 1x36W | 21 | 36 | 10 | 30.5 | 230.58 |
| | LED | 1x18W | 7 | 18 | 10 | 30.5 | 38.43 |
| | FTL | 1x36W | 7 | 36 | 10 | 30.5 | 76.86 |
| | LED | 1x18W | 2 | 18 | 10 | 30.5 | 10.98 |
| | FTL | 1x36W | 3 | 36 | 10 | 30.5 | 32.94 |
| | LED | 1x18W | 3 | 18 | 10 | 30.5 | 16.47 |
| | FTL | 1x36W | 3 | 36 | 10 | 30.5 | 32.94 |
| | LED | 1x18W | 5 | 18 | 10 | 30.5 | 27.45 |
| | FTL | 1x36W | 5 | 36 | 10 | 30.5 | 54.90 |

ENERGY SAVING MEASURES

| Building | Floor | Change | New wattage | New used Qty | New monthly consumption | Monthly saving | Total investment | Payback period |
|---------------|--------------|-----------|-------------|--------------|-------------------------|----------------|------------------|----------------|
| | | | watt | nos | kWh/month | kWh/month | INR | months |
| Main building | Ground floor | No change | 18 | 12 | 27.00 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 40 | 90.00 | 90.00 | 6800 | 5.77 |
| | | No change | 18 | 28 | 63.00 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 3 | 6.75 | 6.75 | 510 | 5.77 |
| | | No change | 18 | 15 | 33.75 | 0.00 | 0 | #DIV/0! |
| | | No change | 18 | 1 | 2.25 | 0.00 | 0 | #DIV/0! |
| | | No change | 18 | 8 | 18.00 | 0.00 | 0 | #DIV/0! |
| | | No change | 18 | 38 | 85.50 | 0.00 | 0 | #DIV/0! |
| | | No change | 18 | 3 | 6.75 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 61 | 137.25 | 137.25 | 10370 | 5.77 |
| | | No change | 18 | 22 | 49.50 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 16 | 36.00 | 36.00 | 2720 | 5.77 |
| | | No change | 18 | 38 | 85.50 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 4 | 9.00 | 9.00 | 680 | 5.77 |
| | | No change | 9 | 25 | 28.13 | 0.00 | 0 | #DIV/0! |
| | | No change | 18 | 13 | 29.25 | 0.00 | 0 | #DIV/0! |
| LED-1x18W | 18 | 20 | 45.00 | 45.00 | 3400 | 5.77 | | |
| LED-1x18W | 9 | 44 | 49.50 | 49.50 | 6600 | 10.18 | | |
| LED-1x18W | 18 | 36 | 81.00 | 81.00 | 6120 | 5.77 | | |

| | | | | | | | | |
|-----------------|--------------|-----------|----|----|--------|--------|-------|---------|
| | | No change | 50 | 24 | 150.00 | -96.00 | 0 | 0.00 |
| | | LED-1x18W | 18 | 50 | 112.50 | 112.50 | 8500 | 5.77 |
| | First floor | LED-1x18W | 18 | 40 | 90.00 | 90.00 | 6800 | 5.77 |
| | | LED-1x18W | 18 | 34 | 76.50 | 76.50 | 5780 | 5.77 |
| | | LED-1x18W | 18 | 7 | 15.75 | 15.75 | 1190 | 5.77 |
| | | LED-1x18W | 18 | 31 | 69.75 | 69.75 | 5270 | 5.77 |
| | | LED-1x18W | 18 | 84 | 189.00 | 189.00 | 14280 | 5.77 |
| | | LED-1x18W | 18 | 51 | 114.75 | 114.75 | 8670 | 5.77 |
| | | No change | 18 | 2 | 4.50 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 32 | 72.00 | 72.00 | 5440 | 5.77 |
| | | No change | 18 | 50 | 112.50 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 99 | 222.75 | 222.75 | 16830 | 5.77 |
| | | No change | 18 | 32 | 72.00 | 0.00 | 0 | #DIV/0! |
| | | No change | 18 | 48 | 108.00 | 0.00 | 0 | #DIV/0! |
| | Second floor | No change | 18 | 5 | 2.25 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 18 | 40.50 | 40.50 | 3060 | 5.77 |
| | | LED-1x18W | 18 | 43 | 96.75 | 96.75 | 7310 | 5.77 |
| | | LED-1x18W | 18 | 19 | 42.75 | 42.75 | 3230 | 5.77 |
| | | LED-1x18W | 18 | 25 | 56.25 | 56.25 | 4250 | 5.77 |
| | | No change | 18 | 45 | 101.25 | 0.00 | 0 | #DIV/0! |
| | | No change | 18 | 86 | 193.50 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 9 | 20.25 | 20.25 | 1530 | 5.77 |
| | | LED-1x18W | 18 | 20 | 45.00 | 45.00 | 3400 | 5.77 |
| | Third floor | No change | 18 | 9 | 20.25 | 0.00 | 0 | #DIV/0! |
| | | LED-1x18W | 18 | 82 | 184.50 | 184.50 | 13940 | 5.77 |
| | | No change | 18 | 88 | 198.00 | 0.00 | 0 | #DIV/0! |
| Premises | | No change | 18 | 15 | 33.75 | 0.00 | 0 | #DIV/0! |

| | | | | | | | |
|---------|-----------|----|-----|--------|--------|-------|---------|
| | LED-1x18W | 18 | 7 | 15.75 | 15.75 | 1190 | 5.77 |
| | No change | 18 | 47 | 105.75 | 0.00 | 0 | #DIV/0! |
| Hostels | No change | 18 | 150 | 337.50 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 72 | 162.00 | 162.00 | 12240 | 5.77 |
| | No change | 18 | 114 | 256.50 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 114 | 256.50 | 256.50 | 19380 | 5.77 |
| | No change | 18 | 95 | 213.75 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 95 | 213.75 | 213.75 | 16150 | 5.77 |
| | No change | 18 | 11 | 24.75 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 4 | 9.00 | 9.00 | 680 | 5.77 |
| | LED-1x18W | 18 | 2 | 4.50 | 4.50 | 340 | 5.77 |
| | No change | 18 | 3 | 16.47 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 2 | 10.98 | 10.98 | 340 | 2.36 |
| | No change | 18 | 20 | 109.80 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 20 | 109.80 | 109.80 | 3400 | 2.36 |
| | No change | 18 | 4 | 21.96 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 3 | 16.47 | 16.47 | 510 | 2.36 |
| | No change | 18 | 15 | 82.35 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 18 | 98.82 | 98.82 | 3060 | 2.36 |
| | No change | 18 | 6 | 32.94 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 6 | 32.94 | 32.94 | 1020 | 2.36 |
| | No change | 18 | 2 | 10.98 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 2 | 10.98 | 10.98 | 340 | 2.36 |
| | No change | 18 | 8 | 43.92 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 9 | 49.41 | 49.41 | 1530 | 2.36 |
| | No change | 18 | 2 | 10.98 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 2 | 10.98 | 10.98 | 340 | 2.36 |

| | | | | | | | |
|--|-----------|----|----|--------|--------|------|---------|
| | No change | 18 | 1 | 5.49 | 0.00 | 0 | #DIV/0! |
| | No change | 18 | 22 | 120.78 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 22 | 120.78 | 120.78 | 3740 | 2.36 |
| | No change | 18 | 6 | 32.94 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 7 | 38.43 | 38.43 | 1190 | 2.36 |
| | LED-1x18W | 18 | 2 | 10.98 | 10.98 | 340 | 2.36 |
| | No change | 18 | 3 | 16.47 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 3 | 16.47 | 16.47 | 510 | 2.36 |
| | No change | 18 | 5 | 27.45 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 4 | 21.96 | 21.96 | 680 | 2.36 |
| | No change | 18 | 4 | 21.96 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 4 | 21.96 | 21.96 | 680 | 2.36 |
| | No change | 18 | 19 | 104.31 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 20 | 109.80 | 109.80 | 3400 | 2.36 |
| | No change | 18 | 4 | 21.96 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 4 | 21.96 | 21.96 | 680 | 2.36 |
| | No change | 18 | 8 | 43.92 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 9 | 49.41 | 49.41 | 1530 | 2.36 |
| | No change | 18 | 2 | 10.98 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 2 | 10.98 | 10.98 | 340 | 2.36 |
| | No change | 18 | 3 | 16.47 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 4 | 21.96 | 21.96 | 680 | 2.36 |
| | No change | 18 | 3 | 16.47 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 3 | 16.47 | 16.47 | 510 | 2.36 |
| | No change | 18 | 12 | 65.88 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 13 | 71.37 | 71.37 | 2210 | 2.36 |
| | No change | 18 | 29 | 159.21 | 0.00 | 0 | #DIV/0! |

| | | | | | | | |
|--|-----------|----|----|--------|--------|------|---------|
| | LED-1x18W | 18 | 29 | 159.21 | 159.21 | 4930 | 2.36 |
| | No change | 18 | 23 | 126.27 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 24 | 131.76 | 131.76 | 4080 | 2.36 |
| | No change | 18 | 4 | 21.96 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 5 | 27.45 | 27.45 | 850 | 2.36 |
| | No change | 18 | 27 | 148.23 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 28 | 153.72 | 153.72 | 4760 | 2.36 |
| | No change | 18 | 24 | 131.76 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 24 | 131.76 | 131.76 | 4080 | 2.36 |
| | No change | 18 | 26 | 142.74 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 26 | 142.74 | 142.74 | 4420 | 2.36 |
| | No change | 18 | 15 | 82.35 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 15 | 82.35 | 82.35 | 2550 | 2.36 |
| | No change | 18 | 6 | 32.94 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 6 | 32.94 | 32.94 | 1020 | 2.36 |
| | No change | 18 | 4 | 21.96 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 4 | 21.96 | 21.96 | 680 | 2.36 |
| | No change | 18 | 21 | 115.29 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 21 | 115.29 | 115.29 | 3570 | 2.36 |
| | No change | 18 | 7 | 38.43 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 7 | 38.43 | 38.43 | 1190 | 2.36 |
| | No change | 18 | 2 | 10.98 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 3 | 16.47 | 16.47 | 510 | 2.36 |
| | No change | 18 | 3 | 16.47 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 3 | 16.47 | 16.47 | 510 | 2.36 |
| | No change | 18 | 5 | 27.45 | 0.00 | 0 | #DIV/0! |
| | LED-1x18W | 18 | 5 | 27.45 | 27.45 | 850 | 2.36 |

| Total lighting savings- College building and Other | | | |
|---|--|---------------|------------------|
| Monthly consumption | | 1500 | kWh/month |
| New monthly consumption | | 960 | kWh/month |
| New monthly saving | | 540 | kWh/month |
| New monthly saving | | 6,480 | INR/month |
| Total Investment | | 30,000 | INR |
| Payback period | | 4.93 | months |

ENERGY SAVING MEASURES- OTHER RECOMMENDATIONS

College can installed motions sensor LED tube lights or bulbs where lighting is on for maximum period and occupancy or motion is less. This save additional energy by automatic switching of lighting.

ENERGY PERFORMANCE ASSESSMENT OF FAN

COLLEGE BUILDING AND OTHERS

OBSERVATION

College has installed old conventional induction motor fan which consumes 65W at full speed. It is recommended that replace old fan which are operated maximum usage per day with new energy efficient fan which consumes 28W at full speed. Also exhaust fan of 50W with 18W energy efficient fans.

ENERGY SAVING MEASURES

| Building | Floor | Qty | Wattage | Hours of usage | No of Days in a month | Monthly consumption | New wattage | New monthly consumption | Monthly saving | Total investment | Payback period |
|---------------|--------------|-----|---------|----------------|-----------------------|---------------------|-------------|-------------------------|----------------|------------------|----------------|
| | | Nos | watt | hrs | days | kWh/day | watt | kWh/month | kWh/month | INR | months |
| Main building | Ground floor | 3 | 70 | 5 | 25 | 26.25 | 28 | 10.50 | 15.75 | 5400 | 26.17 |
| | | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |
| | | 4 | 70 | 5 | 25 | 35.00 | 28 | 14.00 | 21.00 | 7200 | 26.17 |
| | | 4 | 70 | 5 | 25 | 35.00 | 28 | 14.00 | 21.00 | 7200 | 26.17 |
| | | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |
| | | 12 | 70 | 5 | 25 | 105.00 | 28 | 42.00 | 63.00 | 21600 | 26.17 |
| | | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| | | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| | | 6 | 70 | 5 | 25 | 52.50 | 28 | 21.00 | 31.50 | 10800 | 26.17 |
| | | 3 | 70 | 5 | 25 | 26.25 | 28 | 10.50 | 15.75 | 5400 | 26.17 |
| | | 10 | 70 | 5 | 25 | 87.50 | 28 | 35.00 | 52.50 | 18000 | 26.17 |

| | | | | | | | | | | | |
|-----------------|--------------|----|----|---|----|--------|----|-------|--------|-------|-------|
| | | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| | | 4 | 70 | 5 | 25 | 35.00 | 28 | 14.00 | 21.00 | 7200 | 26.17 |
| | First floor | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |
| | | 3 | 70 | 5 | 25 | 26.25 | 28 | 10.50 | 15.75 | 5400 | 26.17 |
| | | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |
| | | 7 | 70 | 5 | 25 | 61.25 | 28 | 24.50 | 36.75 | 12600 | 26.17 |
| | | 14 | 70 | 5 | 25 | 122.50 | 28 | 49.00 | 73.50 | 25200 | 26.17 |
| | | 5 | 70 | 5 | 25 | 43.75 | 28 | 17.50 | 26.25 | 9000 | 26.17 |
| | | 5 | 70 | 5 | 25 | 43.75 | 28 | 17.50 | 26.25 | 9000 | 26.17 |
| | | 9 | 70 | 5 | 25 | 78.75 | 28 | 31.50 | 47.25 | 16200 | 26.17 |
| | | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |
| | | 3 | 70 | 5 | 25 | 26.25 | 28 | 10.50 | 15.75 | 5400 | 26.17 |
| | | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| | Second floor | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| | | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| | | 4 | 70 | 5 | 25 | 35.00 | 28 | 14.00 | 21.00 | 7200 | 26.17 |
| | | 4 | 70 | 5 | 25 | 35.00 | 28 | 14.00 | 21.00 | 7200 | 26.17 |
| | | 3 | 70 | 5 | 25 | 26.25 | 28 | 10.50 | 15.75 | 5400 | 26.17 |
| | | 3 | 70 | 5 | 25 | 26.25 | 28 | 10.50 | 15.75 | 5400 | 26.17 |
| | | 3 | 70 | 5 | 25 | 26.25 | 28 | 10.50 | 15.75 | 5400 | 26.17 |
| | Third floor | 20 | 70 | 5 | 25 | 175.00 | 28 | 70.00 | 105.00 | 36000 | 26.17 |
| | | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| Premises | | 5 | 70 | 5 | 25 | 43.75 | 28 | 17.50 | 26.25 | 9000 | 26.17 |
| | | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |
| Hostels | | 10 | 70 | 5 | 25 | 87.50 | 28 | 35.00 | 52.50 | 18000 | 26.17 |
| | | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |
| | | 1 | 70 | 5 | 25 | 8.75 | 28 | 3.50 | 5.25 | 1800 | 26.17 |

| | | | | | | | | | | |
|--|----|----|---|------|--------|----|-------|--------|-------|-------|
| | 2 | 70 | 5 | 25 | 17.50 | 28 | 7.00 | 10.50 | 3600 | 26.17 |
| | 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| | 2 | 70 | 8 | 30.5 | 34.16 | 28 | 13.66 | 20.50 | 3600 | 13.41 |
| | 2 | 70 | 8 | 30.5 | 34.16 | 28 | 13.66 | 20.50 | 3600 | 13.41 |
| | 4 | 70 | 8 | 30.5 | 68.32 | 28 | 27.33 | 40.99 | 7200 | 13.41 |
| | 5 | 70 | 8 | 30.5 | 85.40 | 28 | 34.16 | 51.24 | 9000 | 13.41 |
| | 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| | 9 | 70 | 8 | 30.5 | 153.72 | 28 | 61.49 | 92.23 | 16200 | 13.41 |
| | 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| | 6 | 70 | 8 | 30.5 | 102.48 | 28 | 40.99 | 61.49 | 10800 | 13.41 |
| | 13 | 70 | 8 | 30.5 | 222.04 | 28 | 88.82 | 133.22 | 23400 | 13.41 |
| | 10 | 70 | 8 | 30.5 | 170.80 | 28 | 68.32 | 102.48 | 18000 | 13.41 |
| | 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| | 4 | 70 | 8 | 30.5 | 68.32 | 28 | 27.33 | 40.99 | 7200 | 13.41 |
| | 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| | 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| | 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| | 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| | 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| | 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| | 2 | 70 | 8 | 30.5 | 34.16 | 28 | 13.66 | 20.50 | 3600 | 13.41 |
| | 5 | 70 | 8 | 30.5 | 85.40 | 28 | 34.16 | 51.24 | 9000 | 13.41 |
| | 2 | 70 | 8 | 30.5 | 34.16 | 28 | 13.66 | 20.50 | 3600 | 13.41 |
| | 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| | 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| | 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| | 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| | 2 | 70 | 8 | 30.5 | 34.16 | 28 | 13.66 | 20.50 | 3600 | 13.41 |
| | 2 | 70 | 8 | 30.5 | 34.16 | 28 | 13.66 | 20.50 | 3600 | 13.41 |
| | 2 | 70 | 8 | 30.5 | 34.16 | 28 | 13.66 | 20.50 | 3600 | 13.41 |


| | | | | | | | | | |
|---|----|---|------|-------|----|-------|-------|------|-------|
| 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| 1 | 70 | 8 | 30.5 | 17.08 | 28 | 6.83 | 10.25 | 1800 | 13.41 |
| 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |
| 3 | 70 | 8 | 30.5 | 51.24 | 28 | 20.50 | 30.74 | 5400 | 13.41 |

| Total fan savings- College building and other | | | |
|--|--|----------------|------------------|
| Monthly consumption | | 1800 | kWh/month |
| New monthly consumption | | 1125 | kWh/month |
| New monthly saving | | 675 | kWh/month |
| New monthly saving | | 8,100 | INR/month |
| Total Investment | | 1,50,00 | INR |
| Payback period | | 18.51 | months |

RENEWABLE ENERGY SYSTEMS


1. SOLAR PHOTOVOLTAIC SYSTEM- ELECTRICAL ENERGY GENERATION

INTRODUCTION



Maharashtra Government has new solar energy policy name as “Rooftop Solar with Net Meter system”. Maharashtra government encourages to install rooftop solar PV system with net meters at available roof top of consumers. This helps to reduce the burden on existing conventional fuel fired power plants in the country.

Solar Rooftop Net meter system helps consumers to reduce the electricity consumption in the electricity bill due to net meter.



OBSERVATION

1. It is observed that in the college has installed Solar PV system of 10 kWp for solar energy generation.
2. College has large rooftop space available for Solar PV system installation.



RECOMMENDATION



1. It is recommended that college can installed additional Solar Photovoltaic (PV) system on available rooftop for solar energy generation.


SAVINGS MEASURES

SAVINGS DUE TO SOLAR PV SYSTEM INSTALLATION- MAIN COLLEGE BUILDING

| Savings due to Solar PV system additional | | |
|--|----------|----------------|
| Total Rooftop space available- approximate | 2429 | sqfoot |
| Average energy consumption of college | 3365 | kWh/month |
| Total capacity of Solar PV system can be installed | 22 | kWp |
| Total solar unit generation | 2484 | kWh/month |
| Average electricity unit rate | 12 | INR/kWh |
| Total cost of Solar PV system | 993681.8 | INR |
| Total saving | 29810.45 | INR/month |
| Payback period | 33.33 | months |
| Payback period | 2.78 | year |
| CO2 emission reduction/year | 25.34 | tonnes of CO2e |

2. BIO-GAS PLANT

INTRODUCTION



Biogas is a mixture of gases, primarily consisting of methane and carbon dioxide, produced from raw materials such as agricultural waste, manure, municipal waste, plant material, sewage, green waste or food waste. It is a renewable energy source.

Biogas is produced by anaerobic digestion with anaerobic organisms or methanogen inside an anaerobic digester, bio digester or a bioreactor.

Biogas is primarily methane (CH_4) and carbon dioxide (CO_2) and may have small amounts of hydrogen sulphide (H_2S), moisture and siloxanes. The gases methane, hydrogen, and carbon monoxide (CO) can be combusted or oxidized with oxygen. This energy release allows biogas to be used as a fuel; it can be used in fuel cells and for any heating purpose, such as cooking. It can also be used in a gas engine to convert the energy in the gas into electricity and heat.

Biogas can be compressed after removal of Carbon dioxide, the same way as natural gas is compressed to CNG, and used to power motor vehicles. In the United Kingdom, for example, biogas is estimated to have the potential to replace around 17% of vehicle fuel. It qualifies for renewable energy subsidies in some parts of the world. Biogas can be cleaned and upgraded to

natural gas standards, when it becomes bio-methane. Biogas is considered to be a renewable resource because its production-and-use cycle is continuous, and it generates no net carbon dioxide. As the organic material grows, it is converted and used. It then regrows in a continually repeating cycle. From a carbon perspective, as much carbon dioxide is absorbed from the atmosphere in the growth of the primary bio-resource as is released, when the material is ultimately converted to energy

Biogas in India has been traditionally based on dairy manure as feed stock and these "gobar" gas plants have been in operation for a long period of time, especially in rural India. In the last 2–3 decades, research organisations with a focus on rural energy security have enhanced the design of the systems resulting in newer efficient low cost designs such as the Deenabandhu model.

The Deenabandhu Model is a new biogas-production model popular in India. (Deenabandhu means "friend of the helpless.") The unit usually has a capacity of 2 to 3 cubic metres. It is constructed using bricks or by a ferrocement mixture. In India, the brick model costs slightly more than the ferrocement model; however, India's Ministry of New and Renewable Energy offers some subsidy per model constructed.

Biogas which is mainly methane/natural gas can also be used for generating protein rich cattle, poultry and fish feed in villages economically by cultivating *Methylococcus capsulatus* bacteria culture with tiny land and water foot print. The carbon dioxide gas produced as by product from these plants can be put to use in cheaper production of algae oil or spirulina from algaculture particularly in tropical countries like India which can displace the prime position of crude oil in near future. Union government of India is implementing many schemes to utilise productively the agro waste or biomass in rural areas to uplift rural economy and job potential. With these plants, the non-edible biomass or waste of edible biomass is converted in to high value products without any water pollution or greenhouse gas (GHG) emissions.

LPG (Liquefied Petroleum Gas) is a key source of cooking fuel in urban India and its prices have been increasing along with the global fuel prices. Also the heavy subsidies provided by the successive governments in promoting LPG as a domestic cooking fuel has become a financial burden renewing the focus on biogas as a cooking fuel alternative in urban establishments. This has led to the development of prefabricated digester for modular deployments as compared to RCC and cement structures which take a longer duration to construct. Renewed focus on process technology like the Biourja process model has enhanced the stature of medium and large scale anaerobic digester in India as a potential alternative to LPG as primary cooking fuel

OBSERVATION

1. In the college canteen approximately 10kg kitchen waste is generated daily.
2. Currently there is no any bio gas plant for generation of bio gas in the college.

RECOMMENDATION



1. It is recommended that installed the small capacity of bio gas plant at college canteen for production of bio gas from kitchen waste generated daily.
2. Produced bio gas can be used for small purposes in the canteen instead of LPG which saves monthly approximate 1 cylinders of INR 950/-

SAVINGS

| Saving due to Bio gas plant | | |
|--------------------------------|--------|-----------------------|
| Capacity of bio gas plant | 10 | kg/day |
| Waste generated | 10 | kg/day |
| Approximate bio gas generation | 0.4 | m ³ /day |
| Approximate bio gas generation | 12 | m ³ /month |
| Equivalent LPG gas saved | 18 | kg/month |
| Approximate LPG cylinder saved | 0.9 | nos |
| Cost saved | 947.37 | INR/month |

ENERGY CONSERVATION BY SAVING OF WATER

TAP WATER REDUCER




| Conventional Tap water system | Tap water system with Reducer |
|---|--|
|  |  |
| <p>Existing tap water system uses more water while during purpose of washing of utensils, hands etc in college.</p> | <p>Used reducer to tap water for purpose of washing of utensils, hands etc which reduces flow of water and ultimately saves the water.</p> |
| <p>⊘</p> | <p>√</p> |

RECOMMENDATION




It is recommended that to use water reducer for water taping for save the water.

ANNEXTURE

ENERGY EFFICIENT FANS


| | |
|---|--|
|  | |
|  | <p>28 watts</p> |
|  | <p>18watts or 8 watts as per size and load</p> |

ENERGY EFFICIENT LIGHTING

| LED Lightings | |
|---|---|
|  | <p>18 watts, 9 watts, 5 watts</p> <p>Companies:</p> <ol style="list-style-type: none"> 1. Wipro 2. Osram 3. Syska 4. Philips <p>etc</p> |
|  | <p>Motion/Heat sensor bulbs</p> <p>Companies:</p> <ol style="list-style-type: none"> 1. Orient electric 2. Halonix <p>etc</p> |
|  | |

ENERGY EFFICIENT INVERTER AC

ENERGY EFFICIENT INVERTER AC



Companies:

1. Daikin
2. Mitsubishi Electric
3. LG
- etc



GREEN & ENVIRONMENT AUDIT REPORT



A.B.M.S PARISHAD'S
YASHWANTRAO CHAVAN LAW COLLEGE

Laxmi Nagar, Parvati Ramana,

Pune, Maharashtra 411009

Phone No: 020 2422 1002

E-mail Id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

Conducted and Submitted by



ENERFUTURE TECHNOLOGY PRIVATE LIMITED

301, Above Ekbote Hospital,

Revenue Colony, J.M.Road,

Pune-411005

Website: <http://www.enerfutureindia.com/utureindia.com>

E-mail: info@enerfutureindia.com

Telephone: +91- 9960041642, 9405065597



SL
PRINCIPAL
Yashwantrao Chavan Law College
Pune-411 009



CERTIFICATE

ENERFUTURE TECHNOLOGY PRIVATE LIMITED
Verified and Certified that



A.B.M.S PARISHAD'S


YASHWANTRAO CHAVAN LAW COLLEGE

LAXMI NAGAR, PARVATI RAMANA,
PUNE, MAHARASHTRA 411009
PHONE NO: 020 2422 1002
E-mail Id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

HAS CARRIED OUT
GREEN (ENVIRONMENT) AUDIT
AS PER GUIDANCE LAID DOWN IN THE
INDIAN STANDARDS AND CODES
IN 2021-22

This certificate is valid for 3 years from 2021-22 to 2023-24



Vinay Mulay
M.Tech (Energy Studies),
Certified BEE Energy Auditor
(EA-10853), Lead Auditor-ISO-50001



Chetan Nemade
M.Tech (Energy Studies), Advance
Diploma
in Industrial Safety (ADIS),
BEE Certified Energy Manager (EA-22697)



Yogesh Kuwar
M.Tech (Energy Studies),
Certified BEE Energy
Manager (EA-33078),
PGDELP, IGBCTM AP-
AA02EEK7



www.enerfuture.com




PRINCIPAL
Yashwantrao Chavan Law College
Pune-411 008

ACKNOWLEDGEMENT AND CONCEPT

Enerfuture Technology Private Limited thanks the management of Yashwantrao Chavan Law College, Pune for assigning this important work of Green and Environment Audit of Yashwantrao Chavan Law College, Pune

Green audit is defined as a formal examination of practices adopted and their effects on the environment, by an organization. It is also widely known as Environmental Audit.

The aim of the Green Audit is to review the overall environment management systems. Depending on the types of standards and the focus of the audit, there are different types of environmental audits.

Organizations now recognize the importance of environmental matters and accepts that their environment performance should be scrutinized to understand its impact and to take remedial measures to lessen it.

Environmental auditing is used to:

1. Investigate
2. Understand and
3. Identify

These are then used to help in improving existing human activities, with the aim of reducing the adverse effects of these activities on the environment.

An environment auditor studies an organization's environment effects in a systematic and documented manner and produces an environmental audit report.

Green audit for an educational institution mainly examines the following systems

1. Renewable/ green energy usage
2. Water management
3. Biodiversity
4. Health and safety management
5. Sanitation management
6. Adopted Green practices

Contribution of college's team is equally important in this venture. Team of technical experts from Enerfuture Technology Private Limited is grateful to all the following personnel of Yashwantrao Chavan Law College, Pune for their kind cooperation, furnishing required data, analysis report and support offered during our visit.

| Name | Designation |
|-----------------------------|-----------------------|
| Ms Dr Subhada Gholap | Principal |
| Mr. Pramod Phadtare | Office Superintendent |
| Mr Ravindra Patil | Assistant professor |

We are also thankful to the other staff members who were actively involved while taking measurements and conducting field study.

STUDY TEAM

| Sr No | Name | Qualification |
|-------|--------------------|--|
| 1 | Mr. Chetan Nemade | M.Tech (Energy Studies), Advance Diploma in Industrial Safety (ADIS), LLB, BEE Certified Energy Manager |
| 2 | Mr Vinay Mulay | M.Tech (Energy Studies), ISO 50001 Lead Auditor, BEE Accredited Energy Auditor |
| 3 | Mr YogeshKumar | M.Tech (Energy Studies), IGBC IGBC Accredited Professional, Post Graduate Diploma in Environmental law and Policy (PGDELP), BEE Certified Energy Manager |
| 4 | Mr Prasad Kalal | B.E Electrical, BE (Electrical), Electrical Supervisor(51242), Electrical Contractor(37364) |
| 5 | Mr Prashant Shinde | B.E Mechanical, IGBC Accredited Professional, Certified Energy Auditor |

LIST OF INSTRUMENTS USED

1. Lux meter (Meco)
2. TDS meter
3. CO2 meter
4. Air quality measure meter
5. Sound dB meter

CONTENTS

| | |
|--|----|
| EXCECUTIVE SUMMARY..... | 8 |
| RENEWABLE ENERGY SYSTEMS..... | 11 |
| 1. SOLAR PHOTOVOLTAIC SYSTEM- ELECTRICAL ENERGY GENERATION | 11 |
| INTRODUCTION | 11 |
| OBSERVATION | 12 |
| RECOMMENDATION | 13 |
| SAVINGS MEASURES..... | 13 |
| SAVINGS DUE TO SOLAR PV SYSTEM INSTALLATION- MAIN COLLEGE BUILDING | 13 |
| 2. SOLAR WATER HEATING SYSTEM- HOT WATER GENERATION..... | 14 |
| OBSERVATION | 14 |
| CO ₂ EMISSION REDUCTION | 15 |
| RECOMMENDATION | 15 |
| WASTE MANAGEMENT SYSTEMS..... | 16 |
| 1. BIO-GAS PLANT..... | 16 |
| INTRODUCTION | 16 |
| OBSERVATION | 18 |
| RECOMMENDATION | 18 |
| SAVINGS..... | 18 |
| 2. TREE PLANTATION/GREEN BELT | 19 |
| OBSERVATION | 19 |
| WATER QUALITY AND MANAGEMENT SYSTEMS | 21 |
| 1. TDS LEVEL OF WATER..... | 21 |
| INTRODUCTION | 21 |
| OBSERVATION | 22 |
| OBSERVATION | 22 |

| | |
|--|----|
| 2. RAIN WATER HARVESTING- COLLEGE PREMISES (SCIENCE BUILDING) | 23 |
| OBSERVATION | 23 |
| 3. WATER TAP REDUCER | 24 |
| OBSERVATION | 24 |
| RECOMMENDATION | 24 |
| AIR QUALITY | 25 |
| INTRODUCTION | 25 |
| OBSERVATION | 26 |
| SOUND COMFORT/QUALITY | 31 |
| INTRODUCTION | 31 |
| OBSERVATION | 32 |
| DAY LIGHT ILLUMINATION/COMFORT | 34 |
| INTRODUCTION | 34 |
| OBSERVATION | 35 |
| HEALTH AND SAFETY MANAGEMENT AND INFRASTRUCTURE | 37 |
| 1. COLLEGE INFRASTRUCTURE | 37 |
| INTRODUCTION | 37 |
| OBSERVATION | 37 |
| ASSESSMENT OF COLLGE CAMPUS BUILDING INFRASTRUCTURE | 38 |
| 2. HEALTH AND SAFETY MANAGEMENT | 39 |
| OBSERVATION | 39 |
| RECOMMENDATION | 39 |
| NO VEHICLE DAY INITIATIVE | 43 |
| OBSERVATION | 43 |
| CO2 EMISSION REDUCTION DUE TO NO VEHICLE DAY | 43 |
| OTHER ENERGY EFFICIENT, GREEN, HEALTH, WASTE PRACTICES BY THE COLLEGE MANAGEMENT | 45 |

| | |
|---|----|
| 1. SOLID WASTE MANAGEMENT (SCRAPS LIKE PLASTIC, PAPER ETC)/ E- WASTE MANAGEMENT | 45 |
| INTRODUCTION | 45 |
| E-WASTE MANAGEMNT | 45 |
| OBSERVATION | 46 |
| 2. TREE PLANTATION, SOIL CONSERVATION ETC | 50 |
| INTRODUCTION | 50 |
| OSERVATION | 50 |
| 3. ENERGY EFFICIENT EQUIPMENTS | 54 |
| INTRODUCTION | 54 |
| OSERVATION | 54 |
| REFERENCES AND STANDARDS | 55 |

EXCECUTIVE SUMMARY

| Sr No | Location | Area | Objective/Purpose | Recommendation/Status |
|-------|--------------------------|---|---|----------------------------------|
| 1 | College building | Solar Photovoltaic System- 10Wp | To generate electrical energy by renewable sources and reduce the CO2 emissions | Implemented |
| 2 | College building | Additional Solar Photovoltaic System- 22 Wp | To generate electrical energy by renewable sources and reduce the CO2 emissions | Can be Implemented |
| 3 | College hostel building | Solar Water Heater System | To generate hot water for hostel use to save the electricity and reduce the CO2 emissions | Implemented |
| 4 | College canteen | Bio-Gas generation plant- 10kg/day | Utilised organic food generated in the hostel mess to generate bio-gas for cooking purpose. This saves conventional fuel LPG and ultimately reduce the CO2 and Greenhouse gases emissions | Can be Implemented |
| 5 | College building | Tap water reducers | To save the water | Can be Implemented |
| | | Hands free water tap system | This saves the water and also good for personal health protection to avoid frequent hand touching to water taps. | Can be Implemented |
| 6 | College building/campus | Rain water harvesting | Save water. Increases the groundwater recharge. | Implemented |
| 7 | College buildings/campus | Air Comfort/ Quality | Air quality for human being comfort | Marginally acceptable |
| 8 | College buildings/campus | Sound Comfort/ Quality | Sound quality or comfort for human being comfort | Within permissible limits |


| | | | | |
|----|--|---|---|--|
| 9 | College buildings/campus | Daylight Comfort/Illumination | Daylight illumination for human being comfort | Within permissible limits |
| 10 | College buildings/campus | Health and Safety Management | Health facility | Ok |
| | | | Electrical safety- electrical wiring, its loose connections etc , unwanted materials are placed in electrical panel rooms | Need to be remove |
| | | | Fire safety- number of fire extinguishers are placed in college campus | OK |
| | | | Fire safety- Maintenance validity of fire extinguishers are updated. | OK |
| 11 | College buildings/campus | No vehicle day | Unwanted material placed in college campus | OK |
| | | | Save the conventional fuel and reduces the CO2 emissions. | Implemented |
| 12 | College buildings/campus | Waste management- Solid waste | Reduce the CO2 emissions by recycling of solid waste | Regularly implemented and maintained every month. |
| 13 | College buildings/campus/other city area | Tree plantation/ Green belt cover | To increase the forest cover. Reduce the Air, Noise pollution, reduce CO2 emissions etc | Regularly conducted by college |
| 14 | College buildings/campus/other city area | Cleanliness drive and awareness campaign or poster competitions etc | To create awareness among students as well as in society/community. | Regularly conducted by college |

| | | | | |
|----|--------------------------|-----------------------|--|--------------------------------|
| 15 | College buildings/campus | Plastic free campaign | Save environment from non-recycling and hazardous materials. | Regularly conducted by college |
|----|--------------------------|-----------------------|--|--------------------------------|

RENEWABLE ENERGY SYSTEMS


1. SOLAR PHOTOVOLTAIC SYSTEM- ELECTRICAL ENERGY GENERATION

INTRODUCTION



Maharashtra Government has new solar energy policy name as “Rooftop Solar with Net Meter system”. Maharashtra government encourages to install rooftop solar PV system with net meters at available roof top of consumers. This helps to reduce the burden on existing conventional fuel fired power plants in the country.

Solar Rooftop Net meter system helps consumers to reduce the electricity consumption in the electricity bill due to net meter.



OBSERVATION

1. It is observed that in the college has installed Solar PV system of 10 kWp for solar energy generation.
2. College has large rooftop space available for Solar PV system installation.



RECOMMENDATION



1. It is recommended that college can installed additional Solar Photovoltaic (PV) system on available rooftop for solar energy generation.

SAVINGS MEASURES

SAVINGS DUE TO SOLAR PV SYSTEM INSTALLATION- MAIN COLLEGE BUILDING

| Savings due to Solar PV system additional | | |
|--|----------|----------------|
| Total Rooftop space available- approximate | 2429 | sqfoot |
| Average energy consumption of college | 3365 | kWh/month |
| Total capacity of Solar PV system can be installed | 22 | kWp |
| Total solar unit generation | 2484 | kWh/month |
| Average electricity unit rate | 12 | INR/kWh |
| Total cost of Solar PV system | 993681.8 | INR |
| Total saving | 29810.45 | INR/month |
| Payback period | 33.33 | months |
| Payback period | 2.78 | year |
| CO2 emission reduction/year | 25.34 | tonnes of CO2e |

2. SOLAR WATER HEATING SYSTEM- HOT WATER GENERATION

OBSERVATION

1. In Boy's hostel and Girl's hostel, there are Solar Water Heating systems are installed for the purpose of water heating instead of electric heaters.
2. Total capacity of Solar Water Heating system is 1000 litres/day each.
3. No any auxiliary heaters are used in solar water heating system in the morning.



CO₂ EMISSION REDUCTION

| Saving due to solar water heating system | | |
|--|----------|-----------------------------|
| Hot water temperature | 60 | deg C |
| Cold water temperature | 25 | deg C |
| Temperature difference(delta T) | 35 | deg C |
| Volume of water | 2000 | lit |
| Volumetric flow | 2000 | lit/day |
| Hot water temperature | 60 | deg C |
| Enthalpy of cold water | 25.04 | kcal/kg |
| Enthalpy of Hot water | 60 | kcal/kg |
| Enthalpy difference | 34.96 | kcal/kg |
| Amount of heat used | 69920 | kcal |
| Power used for heating | 81.30 | kW |
| Monthly kWh | 2479.72 | kWh/month |
| Saving kWh | 2479.72 | kWh/month |
| Saving kWh | 29756.65 | kWh/year |
| Saving Rs | 37493.38 | Rs/month |
| CO ₂ emission reduction/ year | 25.29 | tonnes of CO ₂ e |


RECOMMENDATION

- It is recommended that regularly clean the solar plates for good efficiency.
- Also do the yearly maintenance of solar flat collectors for scale formation inside the tube to increase and maintain the efficiency of the system.

WASTE MANAGEMENT SYSTEMS

1. BIO-GAS PLANT

INTRODUCTION



Biogas is a mixture of gases, primarily consisting of methane and carbon dioxide, produced from raw materials such as agricultural waste, manure, municipal waste, plant material, sewage, green waste or food waste. It is a renewable energy source.

Biogas is produced by anaerobic digestion with anaerobic organisms or methanogen inside an anaerobic digester, bio digester or a bioreactor.

Biogas is primarily methane (CH_4) and carbon dioxide (CO_2) and may have small amounts of hydrogen sulphide (H_2S), moisture and siloxanes. The gases methane, hydrogen, and carbon monoxide (CO) can be combusted or oxidized with oxygen. This energy release allows biogas to be used as a fuel; it can be used in fuel cells and for any heating purpose, such as cooking. It can also be used in a gas engine to convert the energy in the gas into electricity and heat.

Biogas can be compressed after removal of Carbon dioxide, the same way as natural gas is compressed to CNG, and used to power motor vehicles. In the United Kingdom, for example, biogas is estimated to have the potential to replace around 17% of vehicle fuel. It qualifies for renewable energy subsidies in some parts of the world. Biogas can be cleaned and upgraded to natural gas standards, when it becomes bio-methane. Biogas is considered to be a renewable resource because its production-and-use cycle is continuous, and it generates no net carbon dioxide. As the organic material grows, it is converted and used. It then regrows in a continually repeating cycle. From a carbon perspective, as much carbon dioxide is absorbed from the atmosphere in the growth of the primary bio-resource as is released, when the material is ultimately converted to energy

Biogas in India has been traditionally based on dairy manure as feed stock and these "gobar" gas plants have been in operation for a long period of time, especially in rural India. In the last 2–3 decades, research organisations with a focus on rural energy security have enhanced the design of the systems resulting in newer efficient low cost designs such as the Deenabandhu model.

The Deenabandhu Model is a new biogas-production model popular in India. (Deenabandhu means "friend of the helpless.") The unit usually has a capacity of 2 to 3 cubic metres. It is constructed using bricks or by a ferrocement mixture. In India, the brick model costs slightly more than the ferrocement model; however, India's Ministry of New and Renewable Energy offers some subsidy per model constructed.

Biogas which is mainly methane/natural gas can also be used for generating protein rich cattle, poultry and fish feed in villages economically by cultivating *Methylococcus capsulatus* bacteria culture with tiny land and water foot print. The carbon dioxide gas produced as by product from these plants can be put to use in cheaper production of algae oil or spirulina from algaculture particularly in tropical countries like India which can displace the prime position of crude oil in near future. Union government of India is implementing many schemes to utilise productively the agro waste or biomass in rural areas to uplift rural economy and job potential. With these plants, the non-edible biomass or waste of edible biomass is converted in to high value products without any water pollution or greenhouse gas (GHG) emissions.

LPG (Liquefied Petroleum Gas) is a key source of cooking fuel in urban India and its prices have been increasing along with the global fuel prices. Also the heavy subsidies provided by the successive governments in promoting LPG as a domestic cooking fuel has become a financial burden renewing the focus on biogas as a cooking fuel alternative in urban establishments. This has led to the development of prefabricated digester for modular deployments as compared to RCC and cement structures which take a longer duration to construct. Renewed focus on process technology like the Biourja process model has enhanced the stature of medium and large scale anaerobic digester in India as a potential alternative to LPG as primary cooking fuel

OBSERVATION

1. In the college canteen approximately 10kg kitchen waste is generated daily.
2. Currently there is no any bio gas plant for generation of bio gas in the college.

RECOMMENDATION

1. It is recommended that installed the small capacity of bio gas plant at college canteen for production of bio gas from kitchen waste generated daily.
2. Produced bio gas can be used for small purposes in the canteen instead of LPG which saves monthly approximate 1 cylinders of INR 950/-


SAVINGS



| Saving due to Bio gas plant | | |
|--------------------------------|--------|-----------------------|
| Capacity of bio gas plant | 10 | kg/day |
| Waste generated | 10 | kg/day |
| Approximate bio gas generation | 0.4 | m ³ /day |
| Approximate bio gas generation | 12 | m ³ /month |
| Equivalent LPG gas saved | 18 | kg/month |
| Approximate LPG cylinder saved | 0.9 | nos |
| Cost saved | 947.37 | INR/month |

2. TREE PLANTATION/GREEN BELT

OBSERVATION

1. In college premises there are number of trees are planted by college management.
2. College also developed its own horticultural garden as well as nursery.
3. There is substantial amount of waste of tree leaves, shrubs are generated in the college premises.
4. College has initiates the composting plant in the college premises.





WATER QUALITY AND MANAGEMENT SYSTEMS

1. TDS LEVEL OF WATER

INTRODUCTION

The water we drink contains essential salts and minerals like calcium, potassium and magnesium, besides hydrogen and oxygen.



These minerals make up the acceptable levels of TDS (Total Dissolved Solids). Besides, these minerals, the source water contains heavy impurities like arsenic, antimony, lead, iron, etc. It also includes carbonates, fluorides, sulphides and other salts picked along the way. These contaminants enhance the TDS levels to unacceptable levels.

BIS (Bureau of Indian Standards) determines the TDS acceptability levels in drinking water. In India, drinking water can contain TDS up to 500 ppm. BIS has constituted the following table that could clarify the matters further.

| TDS level (PPM) | | Reasons for acceptability or non-acceptance |
|------------------|----------------|--|
| less than 50 | Unacceptable | The water with these TDS level does not contain the minerals required for healthy growth |
| 50 - 150 | Acceptable | Such TDS levels are usually due to minor industrial contamination |
| 150 - 250 | Acceptable | BIS considers water with this TDS levels as the healthiest of all because it is excellent for cardiovascular health |
| 250 - 350 | Acceptable | Many areas in India depends on groundwater or bore wells for their water requirements. This water contains essential minerals hence is in acceptance range |
| 350 - 500 | Fair | The maximum TDS levels acceptable for human consumption is 500 |
| above 500 - 1200 | Not Acceptable | BIS does not recommend any TDS level above 500 as fit for human consumption. However, water with TDS levels up to 1200 can be subjected to purification using Reverse Osmosis(RO) technology to eliminate TDS and bring it down to acceptable levels |

OBSERVATION

1. Drinking water requirement of college fulfil by bore well water as well as PMC water
2. Domestic water requirement of college is fulfil by bore well.
3. For drinking water, in college aqua guard systems are installed to reduce the TDS level of water
4. TDS level of drinking water and domestic water as

| TDS level of water | |
|--|---|
|  |  |
| Drinking water | Domestic water |
| v- Acceptable | v- Acceptable |

| | TDS ppm | Acceptability |
|-----------------------|------------|---------------|
| Drinking water | 63 | Acceptable |
| Domestic water | 61 | Acceptable |


OBSERVATION

1. TDS level of drinking water and domestic water is within permissible level or acceptable

2. RAIN WATER HARVESTING- COLLEGE PREMISES (SCIENCE BUILDING)

OBSERVATION



1. College has implemented rain water harvesting in the college premises.
2. College has large rooftop space and ground where large amount of rain water is saved during rainy season.
3. College reuses rain water at underground water tank. This water tank is either used for garden purposes.



3. WATER TAP REDUCER

OBSERVATION

1. College has conventional water tap system in the area like bathrooms, toilets, laboratories etc.
2. Conventional water tap system consumes or requires more water for the purpose of washings, cleanings etc.

| Conventional Tap water system | Tap water system with Reducer |
|--|--|
|  |  |
| <p>College have installed tap water system at laboratories except other places like bathrooms, kitchen etc</p> | <p>Used reducer to tap water for purpose of washing of utensils, hands etc which reduces flow of water and ultimately saves the water.</p> |
| <p>⊘</p> | <p>√</p> |

RECOMMENDATION

It is recommended that increased the number of water reducers for water taping for save the water in other places like bathrooms, kitchen etc.

AIR QUALITY

INTRODUCTION



Indoor air is considered to be healthy when the air does not contain contamination in harmful concentrations and is acceptable when the majority of people feel satisfied. A human being breathes about 12,000 litres of air every day and is vital for our health. Exposure to hazardous airborne agents present in indoor space causes adverse effects such as respiratory and cardiovascular diseases, allergy and irritation of the respiratory tract and possibly leads to cancer.



Main source of indoor air pollutants are from outdoor air, household cooking (especially cooking with biomass or frying), tobacco smoking, polluted ambient air, cleaning agents, resuspension of dust during the cleaning activities, construction materials and paints, copy machines and printers as well as other human activities. Ambient air pollutant sources are vehicle emissions, thermal power plants, biomass burnings, construction work, unattended debris, open sewage pipes, fossil fuel based power generation and various industrial processes etc.


| Threshold values for indoor air quality parameters | | | | |
|--|----------------|-------------|-----------------------|-------------------|
| Parameters | Classification | | | |
| | Class A | Class B | Class C | |
| Level | Aspirational | Acceptable | Marginally acceptable | |
| CO ₂ | Ambient+350 | Ambient+500 | Ambient+700 | ppm |
| PM _{2.5} | <15 | <25 | <25 | ppm |
| PM ₁₀ | <50 | <100 | <100 | ppm |
| HCHO | | 30 | | µg/m ³ |
| TVOC | <200 | <400 | <500 | µg/m ³ |
| Occupational satisfaction | 90 | 80 | - | % |

OBSERVATION


1. In college air quality is at good/ aspirational level.

| Admin office | Faculty room |
|--|---|
|  |  |
| Marginally acceptable | Marginally acceptable |

| Library | Class room |
|---|--|
|  |  |
| Marginally acceptable | Marginally acceptable |




Admin office




Aspirational

Faculty room




Aspirational

Library




Aspirational

Class room



Aspirational



| Location | CO2 | PM2.5 | PM10 | HCHO | TVOC | Level |
|--------------|-----|-------|------|------|------|-------------------------|
| | ppm | ppm | ppm | ppm | ppm | |
| Admin office | 425 | 34 | 39 | 2 | 5 | Marginally acceptable |
| Faculty room | 455 | 34 | 39 | 1 | 6 | Marginally acceptable |
| Library | 414 | 36 | 41 | 1 | 7 | Marginally acceptable |
| Class room | 435 | 38 | 44 | 0 | 3 | Marginally acceptable I |
| Passage | 382 | 37 | 42 | 2 | 10 | Marginally acceptable |

SOUND COMFORT/QUALITY

INTRODUCTION



Noise is unwanted sound. Ambient noise is all encompassing noise associated with any given environment and is usually a composite of sounds from many sources near and far. Any abnormal sound which irritates human being is called as noise pollution.



Noise is one of the undesirable products of technological civilization. Admits this civilization wherever we go, noise surrounds us. The roar of traffic, the passage of trains and aeroplanes, the bustle of crowds and the working of industry and the public utilities deafens our ears. Even home is invaded by noise. The noise from whatever source it comes from is undoubtedly, physiologically as well as psychologically harmful. Invading environment in dangerous proportions, it is an invisible but insidious form of pollutant Noise as a potentially harmful pollutant is being recognised as a great nuisance these days affecting the quality of the particularly, in urban areas.


The Environment (Protection) Act, 1986, under Sec. 6 has mentioned "Rules to regulate environment (Protection) Act, 1986, under Sec. 6 has mentioned "Rules to regulate environmental pollution". This section has explained the maximum allowable limits of concentrations of various environmental pollutants (including noise) for different areas.

| Air quality standards in respect of Noise | | | |
|---|------------------------|---------------|------------|
| Area code | Category of Area/ Zone | Limits/Levels | |
| | | Day Time | Night Time |
| A | Industrial area | 75 | 70 |
| B | Commercial area | 65 | 55 |
| C | Residential area | 55 | 45 |
| D | Silence zone | 50 | 40 |

OBSERVATION

| Admin office | Faculty room |
|--|---|
|  |  |
| Marginally acceptable | Marginally acceptable |

| Library | Class room |
|---|--|
|  |  |
| Marginally acceptable | Marginally acceptable |



| Location | Limits | Limits/Levels |
|---------------------|-----------|---------------------------|
| | dB | |
| Admin office | 62.3 | within permissible limits |
| Faculty room | 64.1 | within permissible limits |
| Library | 65.8 | within permissible limits |
| Class room | 60.7 | within permissible limits |
| Passage | 69.9 | within permissible limits |

DAY LIGHT ILLUMINATION/COMFORT



INTRODUCTION



Light has significant impact on many body functions, including the nervous system, circadian rhythms, pituitary gland, endocrine system, pineal gland and alertness as these are affected by different wavelengths of light.


Variations over time in lighting conditions, in terms of intensity, illumination levels, distribution, ambient lighting and colour temperature, can stimulate alertness and well-being of people.

| Threshold IL luminance level | | |
|------------------------------|----------------|--------------|
| Building type | Type of space | IL luminance |
| | | Lux |
| Schools | Classrooms | 500 |
| | Corridors | 100 |
| | Teachers rooms | 300 |
| | Libraries | 500 |
| | Offices | 300 |

OBSERVATION

| Admin office | Faculty room |
|--|---|
|  |  |
| Marginally acceptable | Marginally acceptable |

| Library | Class room |
|---|--|
|  |  |
| Marginally acceptable | Marginally acceptable |



| Location | IL luminance | Limits/Levels |
|---|--------------|---------------------------|
| | Lux | |
| M. Pharmaceutics lab | *195 | within permissible limits |
| Class room-04 (Pharma-D) | *138 | within permissible limits |
| Server room | *86 | within permissible limits |
| Computer lab | *22 | within permissible limits |
| Class room-1 | *43 | within permissible limits |
| * values are measured in daylight and given standard values of lux are with lightings | | |

HEALTH AND SAFETY MANAGEMENT AND INFRASTRUCTURE

1. COLLEGE INFRASTRUCTURE

INTRODUCTION

College campus comprises of mainly three buildings as main college building and boys and girls hostel.

OBSERVATION

| Sr. No. | Locations | Space |
|---------|------------------------|----------|
| 1 | Main college building | Spacious |
| 2 | Seminar hall | Spacious |
| 3 | Library & Reading hall | Spacious |
| 4 | Toilet Blocks | Spacious |
| 5 | Parking Area | Spacious |
| 6 | Passage | Spacious |
| 7 | Class rooms | Spacious |
| 8 | Canteen | Spacious |
| 9 | College premises | Spacious |
| 10 | Hostels | Spacious |

ASSESSMENT OF COLLEGE CAMPUS BUILDING INFRASTRUCTURE

| Sr No | Locations | Space | Ventilation | Natural Light | Cleanliness | Remark |
|-------|------------------------|----------|-------------|----------------|-------------|--------|
| 1 | Main college building | Spacious | Good | Good | Good | |
| 2 | Seminar hall | Spacious | Good | Good | Good | |
| 3 | Library & Reading hall | Spacious | Good | Good | Good | |
| 4 | Toilet Blocks | Spacious | Good | Average | Good | |
| 5 | Parking Area | Spacious | Good | Good | Good | |
| 6 | Passage | Spacious | Good | Good | Good | |
| 7 | Class rooms | Spacious | Good | Good | Good | |
| 8 | Canteen | Spacious | Good | Partially good | Good | |
| 9 | College premises | Spacious | Good | Good | Good | |
| 10 | Hostels | Spacious | Good | Good | Good | |



2. HEALTH AND SAFETY MANAGEMENT


OBSERVATION

1. Regular cleaning of college campus and toilets is done by the cleaning staff. This involves dusting, floor cleaning and toilets cleanings.
2. Garden and parking area is also kept clean by staffs.
3. Cleaning equipment and washing liquids are provided to the cleaning staff.
4. Medical kits are placed in office.
5. Fire extinguishers are regularly filled and maintained by college.
6. At various palaces in college premises, floors, offices dust bins are placed.

RECOMMENDATION


1. Open wiring, loose connections and not properly addressed cable wiring have been observed in college, that may lead to short circuits as well as from electrical safety it is dangerous. Also panel doors are not closed properly. So it is an urgent repair and corrected.

| Fire safety | |
|--|--|
| Fire extinguishers | Fire extinguishers |
|  |  |
| <p>College has placed number of fire extinguishers at various places in the college campus</p> | <p>College has placed number of fire extinguishers at various places in the college campus</p> |
| <p>✓- Good</p> | <p>✓- Good</p> |

| Fire safety | |
|--|--|
| Fire Extinguishers maintenance | |
|  | |
| <p>Maintenance validity of fire extinguishers are renewed.</p> | |
| <p>✓- Good</p> | |


Health safety

Conventional water tapping system



College have currently conventional water tapping system

Hands free water tapping system



College can adopts hands free water tapping system. This saves the water and also good for personal health protection to avoid frequent hand touching to water taps.

Health safety

Dust bins



College have number of dust bin at various places for disposal of waste.

Dust bins




College have number of dust bin at various places for disposal of waste.

NO VEHICLE DAY INITIATIVE

OBSERVATION

1. Many of the college students and staff use the private or own vehicle to come college.
2. It contributes the CO₂ emission due to burning of petrol or diesel in the vehicles.

Vehicles in the college premises



CO₂ EMISSION REDUCTION DUE TO NO VEHICLE DAY

| Particulars | | |
|--|--------|-----------------------------|
| Number of vehicles in college premises | 250 | nos |
| Average running of vehicle | 2 | km/vehicle |
| Average fuel required | 250 | litres/day |
| Average cost of fuel | 25000 | INR/day |
| Number of days in months | 4 | nos |
| Average fuel save | 1000 | litres/month |
| Average cost save | 100000 | INR/month |
| Average CO ₂ emission reduction per month | 0.67 | tonnes of CO ₂ e |
| Average CO ₂ emission reduction per year | 8.04 | tonnes of CO ₂ e |

No vehicle day initiative



अखिल भारतीय मराठा शिक्षण परिषद

Registered under Societies Registration Act XXI of 1860
& Bombay Public Trust Act XXIX of 1950
Reg. No. F-75 (P)

पुणे कार्यालय : अखिल भारतीय मराठा शिक्षण परिषदचे कार्यालय पुणे, मध्य कोठी, जेठ्या, जेठ्या, पुणे ४११ ००१
☎ (०२०) २६२५५१२३, २६२२२११०३ ईमेल : abmshiksha@rediffmail.com, yashwantrao@rediffmail.com
मुंबई कार्यालय : अखिल भारतीय मराठा शिक्षण परिषद, बॉम्बे (पुणे), मुंबई ४०० ००१
☎ (०२२) २६२५२०६१

स्थापना : १९०७ - शिवाग्र : १९४४

अध्यक्ष

मा. अश्वतराव जोषितराव पवार

उपाध्यक्ष

मा. अश्वितदाबा अनंतराव पवार

मा. अश्विदास शंकरराव गुंता

जन्मल सेक्रेटरी

मा. प्रमिला भागवतराव गायकवाड

लॉईट सेक्रेटरी

मा. संदीप सुदामराव कवम

मा. अमदातराव बाबुराव साळुंखे

इंजिनियर

मा. विनयमिह यशवंतराव जोषे

अध्यक्ष, नियामक मंडळ

मा. संजय बाबुराव शेठे

अध्यक्ष, पुणे विभागीय

कार्यकारी समिती

मा. अभिमन्यू बोधानी सुर्यवंशी

१२-२२/१५ १९४५

सूचना

अखिल भारतीय मराठा शिक्षण परिषदेचा परिसर हा ६७ एकरचा असून विविध प्रकारच्या वृक्षांमुळे सुंदर दिसतो. बदलत्या पर्यावरणाचा विचार करता काही उपक्रम राबविणे गरजेचे असून पर्यावरण संरक्षण करणेही गरजेचे आहे. तसेच त्याविषयी विद्यार्थ्यांना पर्यावरण संरक्षणाचा चांगला संदेश देण्यासाठी संस्थेने दोन महत्वाचे निर्णय घेतले आहेत.

१. संस्थेच्या परिसरातील सगळ्या महाविद्यालयांनी कमीत कमी प्लॅस्टिकचा वापर करणे व प्रत्येक महिन्याला परिसरातील प्लॅस्टिक गोळा करण्याची मोहीम हाती घेणे.

२. परिसरातील सगळ्या महाविद्यालयांनी आपल्या विद्यार्थ्यांना सूचित करून महिन्यातून एक दिवस 'नो वेहिकल' (विनावाहन दिवस) दिवस पाळण्यात यावा.



(Signature)

संरक्षिणीस

अखिल भारतीय मराठा शिक्षण परिषद पुणे

प्रत- श्री शाहू मंदिर महाविद्यालय पुणे

यशवंतराव चव्हाण विधी महाविद्यालय पुणे

अनंतराव पवार कॉलेज ऑफ इंजिनियरिंग पुणे

अनंतराव पवार कॉलेज ऑफ अर्कीटेक्चर पुणे

श्री नामदेवराव सुर्यवंशी औद्योगिक प्रशिक्षण संस्था पुणे

THE ENERGY EFFICIENT, GREEN, HEALTH, WASTE PRACTICES BY THE COLLEGE MANAGEMENT

1. SOLID WASTE MANAGEMENT (SCRAPS LIKE PLASTIC, PAPER ETC)/ E-WASTE MANAGEMENT

INTRODUCTION

College have good policy and maintained the record for solid waste generated in the college like old newspapers, books, scrap boxes, etc.

E-WASTE MANAGEMENT

Electronic waste or e-waste describes discarded electrical or electronic devices. Used electronics which are destined for reuse, resale, salvage, recycling, or disposal are also considered e-waste. Informal processing of e-waste in developing countries can lead to adverse human health effects and environmental pollution.

Electronic scrap components, such as CPUs, contain potentially harmful components such as lead, cadmium, beryllium, or brominated flame retardants. Recycling and disposal of e-waste may involve significant risk to health of workers and communities in developed countries and great care must be taken to avoid unsafe exposure in recycling operations and leaking of materials such as heavy metals from landfills and incinerator ashes.


The environmental impact of the processing of different electronic waste components

| E-Waste Component | Process Used | Potential Environmental Hazard |
|---|---|---|
| Cathode ray tubes (used in TVs, computer monitors, ATM, video cameras, and more) | Breaking and removal of yoke, then dumping | Lead, barium and other heavy metals leaching into the ground water and release of toxic phosphor |
| Printed circuit board (image behind table – a thin plate on which chips and other electronic components are placed) | De-soldering and removal of computer chips, open burning and acid baths to remove metals after chips are removed. | Air emissions and discharge into rivers of glass dust, tin, lead, brominated dioxin, beryllium cadmium, and mercury |
| Chips and other gold plated components | Chemical stripping using nitric and hydrochloric acid and burning of chips | PAHs, heavy metals, brominated flame retardants discharged directly into rivers acidifying fish and flora. Tin and lead contamination of surface and groundwater. Air emissions of brominated dioxins, heavy metals, and PAHs |
| Plastics from printers, keyboards, monitors, etc. | Shredding and low temp melting to be reused | Emissions of brominated dioxins, heavy metals, and hydrocarbons |
| Computer wires | Open burning and stripping to remove copper | PAHs released into air, water, and soil. |

OBSERVATION

1. College has given solid waste generated like papers, metal scrap, garden waste etc to the authorised recycle for proper channelling the solid waste.
2. This helps to reduce the CO2 emission reduction due to recycling of the solid waste.
3. Currently college also given E-waste to the authorised recycler viz Agasti computer, Pune
4. College regularly giving scrap to the authorised dealer viz Arpha enterprises, Pune
5. Other waste is managed and given to the Pune Municipal corporation

Scrap receipt etc



Scrap receipt etc

A.B.M.S. Parishad's

YASHWANTRAO CHAVAN LAW COLLEGE

Parvati Ramana, Pune - 411 009.

RECEIPT

Diploma

Receipt No. 2233

Date 9/9/2021

Received with thanks from Mr/Miss Aarta Enterprises, Pune

a sum of Rupees Twenty Two Thousand One Hundred Thirty

on account of Sale of Raddi (Old News paper & Scrap) only


by Cash/Cheque No. Cash drawn on _____

Rs. 22,130/-

(Subject to realization of cheque)

Receiving Clerk's Signature

E-waste



No plastic initiative



अखिल भारतीय मराठा शिक्षण परिषद

Registered under Societies Registration Act XXI of 1860
& Bombay Public Trust Act XXIX of 1950
Reg. No. F-75 (P)

पुणे कार्यालय : अखिल भारतीय मराठा शिक्षण परिषदेचे प्रशासकीय कनिष्ठ, शाहू मंदिर कॉम्प्लेक्स, पर्वणी, पुणे - ४११ ००१

☎ (०२०) २६२१५५२२, २६२२०३८३ Email: abmshiksha@rediffmail.com वेबसाईट: www.abmshiksha.org

पुर्वद कार्यालय : शाहू मंदिर शाहू महाराज विद्यापीठ कनिष्ठ, शाहू (पुणे), पुर्वद ४११ ००१

☎ (०२०) २६२२०६८१

स्थापना : १९०६ - शाखांक : १३४

अध्यक्ष

मा. शाहूदराब मोहितराब पवार

उपाध्यक्ष

मा. अर्जुनदास अनंतराब पवार

मा. शशिजोत शंकरराब सुतार

जनरल सेक्रेटरी

मा. प्रमिला भागवतराब जायकबाद

जॉईंट सेक्रेटरी

मा. संदीप सुरामराब कवस

मा. भगवानराब बाबुराब भाळुंसे

इंजिनियर

मा. विजयसिंह धशवंतराब जेधे

अध्यक्ष, निष्पत्तिक मंडळ

मा. संजय बाबुराब शेटे

राष्ट्रपति, पुणे विभागीय

कार्यकारी समिती

मा. अभिमन्यू दाशानी सूर्यवंशी

दि. २०/०२/२०२०

सूचना

अखिल भारतीय मराठा शिक्षण परिषदेचा परिसर हा ६७ एकराचा अगून विविध प्रकारच्या वृक्षामुळे सुंदर दिमतो. बदलत्या पर्यावरणाचा विचार करता काही उपक्रम राबविणे गरजेचे असून पर्यावरण संरक्षण करणेही गरजेचे आहे. तसेच त्याविषयी विद्यार्थ्यांना पर्यावरण संरक्षणाचा चांगला संदेश देण्यासाठी संस्थेने दोन महत्वाचे निर्णय घेतले आहेत.

१. संस्थेच्या परिसरातील सगळ्या महाविद्यालयांनी कमीत कमी प्लॅस्टिकचा वापर करणे व प्रत्येक महिन्याला परिसरातील प्लॅस्टिक गोळा करण्याची मोहीम हाती घेणे.

२. परिसरातील सगळ्या महाविद्यालयांनी आपल्या विद्यार्थ्यांना सूचित करून महिन्यातून एक दिवस 'नो वेहिकल' (विनावाहत दिवस) दिवस पाळण्यात यावा.



S. J. J. J.

सरचिटणीस

अखिल भारतीय मराठा शिक्षण परिषद पुणे

प्रत- श्री शाहू मंदिर महाविद्यालय पुणे

पशवंतराब चव्हाण विधी महाविद्यालय पुणे

अनंतराब पवार कॉलेज ऑफ इंजिनियरिंग पुणे

अनंतराब पवार कॉलेज ऑफ अर्कीटेक्चर पुणे

श्री नामदेवराव सूर्यवंशी औद्योगिक प्रशिक्षण संस्था पुणे

2. TREE PLANTATION, SOIL CONSERVATION ETC

INTRODUCTION

Tree-planting is the process of transplanting tree seedlings, generally for forestry, land reclamation, or landscaping purpose

In silviculture the activity is known as reforestation, or afforestation, depending on whether the area being planted has or has not recently been forested. It involves planting seedlings over an area of land where the forest has been harvested or damaged by fire, disease or human activity. Tree planting is carried out in many different parts of the world, and strategies may differ widely across nations and regions and among individual reforestation companies. Tree planting is grounded in forest science, and if performed properly can result in the successful regeneration of a deforested area. Reforestation is the commercial logging industry's answer to the large-scale destruction of old growth forests, but a planted forest rarely replicates the biodiversity and complexity of a natural forest.[citation needed]

Because trees remove carbon dioxide from the air as they grow, tree planting can be used as a geoengineering technique to remove CO

2 from the atmosphere. Desert greening projects are also motivated by improved biodiversity and reclamation of natural water systems, but also improved economic and social welfare due to an increased number of jobs in farming and forestry.

Canopies in tropical and temperate forests can be important habitats for many animals and plants. A dense canopy cover will let little light reach the ground and will lower temperatures.

The canopy protects the ground from the force of rainfall and makes wind force more moderate

OSERVATION

1. In the college premises there are number of trees which are maintained by the college.
2. College also took initiative of tree plantation with the help of students in the city area.

Tree plantation activities/ Cleanliness drive etc



Tree plantation activities/ Cleanliness drive etc



Tree plantation activities/ Cleanliness drive etc




3. ENERGY EFFICIENT EQUIPMENTS

INTRODUCTION

Due to climate change and CO2 emission it is necessary to use energy efficient technologies. It helps to reduce the energy consumption without affecting the output. It also helps the reduced the CO2 emission reductions.

OSERVATION

1. College has taken step by step intuitive to implement various energy efficient equipment/technologies the the college.
2. College has implemented various energy efficient equipment like lighting, Air conditioners, Fridge etc



REFERENCES AND STANDARDS

1. Bureau of Energy Efficiency (BEE), Ministry of Power, Government of India
2. Energy Conservation Building Code (ECBC), 2007, BEE, Government of India
3. Indian Green Building Council (IGBC), India
4. National Ambient Air Quality Standards, 2009, Central Pollution Control Board (CPCB), Government of India
5. The Noise (Pollution and Control) Rules, 2000 Government of India
6. Municipal Solid Wastes (Management and Handling) Rules, 2000, Government of India
7. Solid Waste Management Rules, 2015, Government of India
8. E-waste (Management) Rules, 2015, Government of India
9. Plastic Waste (Management and Handling) Rules, 2016, Government of India
10. National Electrical Code, 2011
11. Fire Extinguisher Standards, 2190-2010, Bureau of Indian Standards (BIS)
12. IS 14489-1998, Code of Practice of Occupational and Health audit
13. Indian Society of Heating, Refrigerating and Air Conditioning Engineers (ISHRAE)



CERTIFICATE

ENERFUTURE TECHNOLOGY PRIVATE LIMITED

Verified and Certified that



A.B.M.S PARISHAD'S

YASHWANTRAO CHAVAN LAW COLLEGE

LAXMI NAGAR, PARVATI RAMANA,

PUNE, MAHARASHTRA 411009

PHONE NO: 020 2422 1002

E-mail Id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

HAS CARRIED OUT

GREEN (ENVIRONMENT) AUDIT

AS PER GUIDANCE LAID DOWN IN THE

INDIAN STANDARDS AND CODES

IN 2021-22

This certificate is valid for 3 years from 2021-22 to 2023-24

Mulay

Vinay Mulay

M.Tech (Energy Studies),

Certified BEE Energy Auditor

(EA-10853), Lead Auditor-ISO-50001

Nemade

Chetan Nemade

M.Tech (Energy Studies), Advance

Diploma

in Industrial Safety (ADIS),

BEE Certified Energy Manager (EA-22697)

Kuwar

Yogesh Kuwar

M.Tech (Energy Studies),

Certified BEE Energy


Manager (EA-33078),

PGDELP, IGBCTM AP-

AA02EEK7



www.ienerfuture.com



Kuwar
PRINCIPAL
Yashwantrao Chavan Law College
Pune

CERTIFICATE

ENERFUTURE TECHNOLOGY PRIVATE LIMITED

Verified and Certified that



A.B.M.S PARISHAD'S

YASHWANTRAO CHAVAN LAW COLLEGE

LAXMI NAGAR, PARVATI RAMANA,

PUNE, MAHARASHTRA 411009

PHONE NO: 020 2422 1002

E-mail Id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

HAS CARRIED OUT

ENERGY AUDIT


AS PER GUIDANCE LAID DOWN IN THE

ENERGY CONSERVATION ACT-2001,

MINISTRY OF POWER, GOVERNMENT OF INDIA

IN 2021-22

This certificate is valid for 3 years from 2021-22 to 2023-24




Vinay Mulay

M.Tech (Energy Studies),

Certified BEE Energy Auditor

(EA-10853), Lead Auditor-ISO-50001



Chetan Nemade

M.Tech (Energy Studies), Advance

Diploma

in Industrial Safety (ADIS),

BEE Certified Energy Manager (EA-22697)



Yogesh Kuwar

M.Tech (Energy Studies),

Certified BEE Energy

Manager (EA-33078),

PGDELP, IGBCTM AP-

AA02EEK7



PRINCIPAL

Yashwantrao Chavan Law College

Pune-411 009

ENVIRONMENT AUDIT REPORT

(ENERGY AUDIT AND GREEN AUDIT)

A.B.M.S PARISHAD'S



YASHWANTRAO CHAVAN LAW COLLEGE

Laxmi Nagar, Parvati Ramana,

Pune, Maharashtra 411009

Phone No: 020 2422 1002

E-mail Id: yclawcollege@gmail.com

Website: www.yclawcollegepune.org

Conducted and Submitted by



ENERFUTURE PVT LTD

301, Above Ekbote Hospital,

Revenue Colony, J.M.Road,

Pune-411005

Website: <http://www.enerfutureindia.com/utureindia.com>

E-mail: info@enerfutureindia.com

Telephone: +91- 9423180029

ACKNOWLEDGEMENT

Enerfuture thanks the management of Yashwantrao Chavan Law College, Pune for assigning this important work of Environment Audit of Yashwantrao Chavan Law College, Pune

Environment Audit study is a joint venture exercise of consultant and college/industry/residential society to account and contain energy usage without sacrificing the purpose of energy use.

Contribution of society's team is equally important in this venture. Team of technical experts from Enerfuture Pvt Ltd is grateful to all the following personnel of Yashwantrao Chavan Law College, Pune for their kind cooperation, furnishing required data, analysis report and hospitality offered during our visit.

| Name | Designation |
|----------------------|-----------------------|
| Ms Dr Subhada Gholap | Principal |
| Mr. Pramod Phadtare | Office Superintendent |
| Mr Ravindra Patil | Assistant professor |

We are also thankful to the other staff members who were actively involved while taking measurements and conducting field study.

STUDY TEAM

| Sr No | Name |
|-------|--------------------|
| 1 | Mr. Chetan Nemade |
| 2 | Mr Swapnil Gaikwad |
| 3 | Mr Ganesh Nikam |

LIST OF INSTRUMENTS USED

1. Single Phase Power Analyzer (Germany)
2. Water Flowmeter (Fuji Electric , Japan))
3. Distance Meter (Bosch)
4. Lux meter (Meco)

EXCECUTIVE SUMMARY

ENERGY AUDIT

| Sr no | Location | Area | Proposed Action | Expected Result | Saving Potential | Monetary Saving | Investment | Payback Period |
|---------------|---------------------------|--|--|--|------------------|-----------------|------------|----------------|
| | | | | monthly | kWh | Rs | Rs | months |
| 1 | Main college building | Lightning recommendations | Replace existing old conventional 1x36W and 2x36W FTL with new energy efficient 1x18W LED tube light battens | Existing lighting consumption= 216.89kWh | 120.41 | 1204.1 | 12,000 | 9.97 |
| | | | | Expected energy consumption= 96.48kWh | | | | |
| | | | | Total energy saved per month=216.89-96.48=120.41kWh | | | | |
| | Boy's hostel | Lightning recommendations | Replace existing old conventional 1x36W with new energy efficient 1x18W LED tube light battens | Existing lighting consumption= 405.90kWh | 202.8 | 2133.46 | 22,500 | 10.55 |
| | | | | Expected energy consumption= 203.10kWh | | | | |
| | | | | Total energy saved per month=405.90-203.10=202.80kWh | | | | |
| Girl's hostel | Lightning recommendations | Replace existing old conventional fans which consumes 65W with new energy efficient fans which | Existing lighting consumption= 301.55kWh | 152.02 | 2298.54 | 18,600 | 8.09 | |
| | | | Expected energy consumption= 149.53kWh | | | | | |

| | | | | | | | | |
|---|-----------------------|----------------------------------|--|--|--------|----------|----------|-------|
| | | | consumes 28W at places where is maximum usage | Total energy saved per month= $301.55-149.53=152.02\text{kWh}$ | | | | |
| 2 | Main college building | Fan recommendations | Replace existing old conventional fans which consumes 65W with new energy efficient fans which consumes 28W at places where maximum usage | Existing fan consumption= 387.01kWh | 220.3 | 2203 | 1,27,200 | 57.74 |
| | | | | Expected energy consumption= 166.71kWh | | | | |
| | | | | Total energy saved per month= $387.01-166.71=220.3\text{kWh}$ | | | | |
| | Boy's hostel | Fan recommendations | Replace existing old conventional fans which consumes 65W with new energy efficient fans which consumes 28W at places where is maximum usage | Existing fan consumption= 590.10kWh | 300.3 | 3159.16 | 1,65,600 | 52.42 |
| | | | | Expected energy consumption= 289.8kWh | | | | |
| | | | | Total energy saved per month= $590.10-289.8=300.3\text{kWh}$ | | | | |
| | Girl's hostel | Fan recommendations | Replace existing old conventional fans which consumes 65W with new energy efficient fans which consumes 28W at places where is maximum usage | Existing fan consumption= 341.25kWh | 194.25 | 2937.06 | 84,000 | 28.6 |
| | | | | Expected energy consumption= 147.0kWh | | | | |
| | | | | Total energy saved per month= $341.25-147.0=194.25\text{kWh}$ | | | | |
| 3 | Main college building | Electricity duty recommendations | As per Maharashtra electricity duty act-1948 and revised-2016 electricity duty is exempted for colleges, its hostels etc | Average monthly electricity duty of main college =1000 Rs | - | 12993.38 | 10,000 | 0.77 |
| | Boy's hostel | | | Average monthly electricity duty of boy's hostel=5912 Rs | | | | |
| | Girl's hostel | | | Average monthly electricity duty of girl's hostel=6081.38 Rs | | | | |

| | | | | | | | | |
|--------------|---------------|---------------|---|-----------------------------------|---------------|----------------|---------------|--------------|
| 4 | Girl's hostel | Tariff change | Existing tariff of girl's college is LT-3 phase residential. But applicable tariff to girl's hostel is LT-X-B-I (0-20kW) as per MSEDCL tariff order | Average monthly saving=13395.2 Rs | - | 13395.2 | 50,000 | 3.73 |
| Total | | | | | 931.95 | 40323.9 | 489900 | 21.48 |

CONTENTS

| | |
|--|----|
| ACKNOWLEDGEMENT | 2 |
| STUDY TEAM | 2 |
| LIST OF INSTRUMENTS USED | 2 |
| EXECUTIVE SUMMARY | 3 |
| ENERGY AUDIT | 3 |
| CONTENTS | 6 |
| COLLEGE INTRODUCTION | 9 |
| INTRODUCTION | 9 |
| LOCATION | 9 |
| ENERGY AUDIT | 10 |
| ELECTRICITY BILL SUMMARY | 11 |
| ELECTRICITY BILL SUMMARY | 11 |
| TOTAL DEPARTMENT WISE % ENERGY CONSUMPTION | 13 |
| OBSERVATION | 13 |
| ENERGY PERFORMANCE ASSESSMENT OF LIGHTING | 14 |
| 1. MAIN COLLEGE BUILDING | 14 |
| OBSERVATION | 14 |
| PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM | 15 |
| ENERGY SAVING MEASURES | 18 |
| 2. BOY'S HOSTEL | 21 |
| OBSERVATION | 21 |
| PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM | 22 |
| ENERGY SAVING MEASURES | 24 |
| 3. GIRL'S HOSTEL | 28 |
| OBSERVATION | 28 |

| | |
|---|----|
| PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM | 29 |
| ENERGY SAVING MEASURES | 31 |
| ENERGY PERFORMANCE ASSESSMENT OF FAN | 34 |
| 1. MAIN COLLEGE BUILDING | 34 |
| OBSERVATION | 34 |
| ENERGY SAVING MEASURES | 34 |
| 2. BOY'S HOSTEL | 36 |
| ENERGY SAVING MEASURES | 36 |
| 3. GIRL'S HOSTEL | 39 |
| ENERGY SAVING MEASURES | 39 |
| SAVING BY TARIFF CHANGE AND ELECTRICITY DUTY | 41 |
| OBSERVATION | 41 |
| SAVINGS MEASURES | 41 |
| SAVINGS DUE TO ELECTRICITY DUTY | 41 |
| SAVINGS DUE TO TARIFF CHANGE OF GIRL'S HOSTEL | 41 |
| CO ₂ EMISSION REDUCTION | 42 |
| GREEN AUDIT | 43 |
| EXCECUTIVE SUMMARY | 44 |
| SOLAR WATER HEATING SYSTEM..... | 46 |
| OBSERVATION | 46 |
| CO ₂ EMISSION REDUCTION | 46 |
| SOLAR PHOTOVOLTAIC SYSTEM | 47 |
| OBSERVATION | 47 |
| TAP WATER REDUCER | 48 |
| 1. TAP WATER REDUCER | 48 |
| RECOMMENDATION | 48 |
| WINDOW DIRECTION IN THE COLLEGE..... | 49 |

| | |
|--|----|
| TREE PLANTATION AND TREE OR FOREST COVER IN THE COLLEGE PREMISES | 50 |
| TREE PLANTATION- 2019-20 | 52 |
| WASTE MANAGEMENT- E-WASTE | 55 |
| RECOMMENDATION | 55 |
| WASTE MANAGEMENT- SOLID WASTE | 56 |
| WASTE MANAGEMENT- SOLID WASTE | 56 |
| WASTE MANAGEMENT- ORGANIC WASTE | 57 |
| RAIN WATER HARVESTING | 58 |
| CLEANLINESS DRIVE AND AWARENESS CAMPAIGN | 59 |
| CLEANLINESS DRIVE AND AWARENESS CAMPAIGN- 2019-20 | 59 |
| PLASTIC FREE CAMPUS CAMPAIGN | 62 |
| SINGLE USED PLASTIC FREE - 2019-20 | 62 |
| NO VEHICLE DAY | 64 |
| RECOMMENDATION | 64 |
| ANNEXTURE | 65 |
| TOTAL SAVING- MAIN COLLEGE | 65 |
| TOTAL SAVING- BOY'S HOSTEL | 65 |
| TOTAL SAVING- GIRL'S HOSTEL | 65 |

COLLEGE INTRODUCTION


INTRODUCTION



Yashwantrao Chavan Law College was established in June 1978. In the beginning, the college was known as A. B. M. S. Parishad's Law College. However, in the year 1987, in the memory of our country's great visionary leader, Late Shri Yashwantrao Chavan, who rose to the height of Deputy of Prime Minister, the college was named after him, as a mark of respect and honour towards him.

The College has its own spacious building which is located in the same campus of A B M S Parishad and which is constructed as per norms laid down UGC. The building was inaugurated on 20th February, 2005 at the auspicious hands of Honourable Shri Sharadrao Pawar (Then Agriculture Minister, Government of India and the President of A B M S Parishad) in presence of Mr. Ajit Pawar (Ex-Deputy Chief Minister, Govt. of Maharashtra)

LOCATION



ENERGY AUDIT

ELECTRICITY BILL SUMMARY

Yashwantrao Chavan Law College has one MSEDCL three phase LT electricity connection in the main college building and other two have in boy's hostel and girl's hostel.

The major electricity consumption in main college building is lighting and fans during college hours. In boy's and girl's hostel lighting, fans and water pump are main electricity consuming utilities.

ELECTRICITY BILL SUMMARY

1. MAIN COLLEGE BUILDING ELECTRICITY BILL SUMMARY

| Meter No | | 160240191081 | | | |
|----------------|-------------|--|------------------|-------------|-------------------|
| BU | | 4605 | | | |
| Connected load | | 15 | | kW | |
| Meter | | LT-X-B-I, 0-20kW Pub Sector others 3-phase | | | |
| | Total units | Adjusted units | Electricity duty | Total Bill | Average Unit Rate |
| | kWh | kWh | Rs | Rs/month | Rs/kWh |
| Aug-18 | 847 | 0 | 1365.35 | 7943.57 | 9.38 |
| Sep-18 | 1044 | 0 | 1724.89 | 10033.01 | 9.61 |
| Oct-18 | 1289 | 0 | 2258 | 13126.92 | 10.18 |
| Nov-18 | 1223 | 0 | 2243.46 | 13037.18 | 10.66 |
| Dec-18 | 0 | 0 | 0 | 350 | 0.00 |
| Jan-19 | 0 | 0 | 0 | 350 | 0.00 |
| Feb-19 | 3785 | 1957 | 3446.36 | 20230.19 | 5.34 |
| Mar-19 | 668 | 291 | 478.45 | 2812.23 | 4.21 |
| Apr-19 | 640 | 1 | 74.96 | 432.12 | 0.68 |
| May-19 | 541 | 0 | 0 | 350 | 0.65 |
| Jun-19 | 770 | 257 | 429.13 | | 0.00 |
| Jul-19 | 493 | 197 | 312 | 1835.23 | 3.72 |
| Aug-19 | 836 | 207 | 1028.44 | 6045.52 | 7.23 |
| Average | 934 | | 13361 | 6379 | |

2. BOY'S HOSTEL ELECTRICITY BILL SUMMARY


| Meter No | | 170012480744 | | |
|----------------|-------------|--|--------------|-------------------|
| BU | | 4605 | | |
| Connected load | | 1 | | kW |
| Meter | | LT-X-B-I, 0-20kW Pub Sector others 3-phase | | |
| | Total units | Electricity duty | Total Bill | Average Unit Rate |
| | kWh | Rs | Rs/month | Rs/kWh |
| Sep-18 | 3066 | 5172.8 | 30082.35 | 9.81 |
| Oct-18 | 3748 | 6662.81 | 38729.29 | 10.33 |
| Nov-18 | 1983 | 3667.1 | 21308.72 | 10.75 |
| Dec-18 | 2150 | 3741.33 | 21751.57 | 10.12 |
| Jan-19 | 2627 | 4700.26 | 27319.94 | 10.40 |
| Feb-19 | 2627 | 4775.82 | 28017.98 | 10.67 |
| Mar-19 | 2627 | 4625.13 | 27149.73 | 10.33 |
| Apr-19 | 100 | 197.76 | 1158.5 | 11.59 |
| May-19 | 10485 | 18728.87 | 109910.31 | 10.48 |
| Jun-19 | 2097 | 3838.91 | 22518.72 | 10.74 |
| Jul-19 | 5070 | 9184.9 | 53887.83 | 10.63 |
| Aug-19 | 3192 | 5648.29 | 33152.69 | 10.39 |
| Average | 3314 | 70944 | 34582 | 10.52 |

3. GIRL'S HOSTEL ELECTRICITY BILL SUMMARY

| Meter No | | 160240583884 | | |
|----------------|-------------|---------------------------|--------------|-------------------|
| BU | | 4605 | | |
| Connected load | | 25 | | kW |
| Meter | | LT-I, Residential 3-phase | | |
| | Total units | Electricity duty | Total Bill | Average Unit Rate |
| | kWh | Rs | Rs/month | Rs/kWh |
| Sep-18 | 3948 | 8350.96 | 60544.48 | 15.34 |
| Oct-18 | 4424 | 9138.9 | 66261.45 | 14.98 |
| Nov-18 | 2500 | 5290.51 | 38356.18 | 15.34 |
| Dec-18 | 2868 | 5736.95 | 41593.12 | 14.50 |
| Jan-19 | 3173 | 6486.48 | 47032.43 | 14.82 |
| Feb-19 | 3429 | 7169.6 | 51979.75 | 15.16 |
| Mar-19 | 3269 | 6630.62 | 48072.2 | 14.71 |
| Apr-19 | 2780 | 5968.69 | 43280.19 | 15.57 |
| May-19 | 2568 | 5622.14 | 40769.21 | 15.88 |
| Jun-19 | 1114 | 2192.08 | 15893.77 | 14.27 |
| Jul-19 | 2111 | 4516.97 | 32748.21 | 15.51 |
| Aug-19 | 2763 | 5872.61 | 42576.88 | 15.41 |
| Average | 2912 | 72977 | 44092 | 15.12 |

TOTAL DEPARTMENT WISE % ENERGY CONSUMPTION

| Facility | Total units | Solar units generation | Amount | Average unit rate | % of energy consumption |
|------------------------------|-------------|------------------------|--------------|-------------------|-------------------------|
| | kWh/month | kWh/month | Rs/month | Rs/kWh | % |
| Main college building | 934 | 416 | 6379 | 6.83 | 13.04 |
| Boy's hostel | 3314 | 0 | 34582 | 10.44 | 46.28 |
| Girl's hostel | 2912 | 0 | 44092 | 15.14 | 40.67 |
| Total | 7160 | 416 | 85053 | 32.40637 | 100 |



OBSERVATION

1. Total monthly energy consumption of the college is 7160 units.
2. Total monthly billing is Rs 85,053/-
3. Girl's hostel energy consumption is more and it's approximately 46% of total energy use.
4. Boy's hostel energy consumption is second after girl's hostel and it's 41% of total energy use.
5. College's energy consumption is less due to implementation of solar photovoltaic system and its 13% of total energy use.
6. 10kWp Solar PV system is installed in main college building as a renewable energy source.


ENERGY PERFORMANCE ASSESSMENT OF LIGHTING

1. MAIN COLLEGE BUILDING

OBSERVATION

College has installed new energy efficient LED lighting in the main college building. There are old conventional lightings are also in the college in use.

| Type | Quantity | kW load | % load |
|-------------------------|-----------|-------------|------------|
| LED lights | 38 | 0.73 | 51.35 |
| Old conventional lights | 36 | 1.37 | 48.65 |
| Total | 74 | 2.10 | 100 |



PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM

| Floor | Room | Name | Light Type | Type | Ballast | Qty | Wattage | Hours of usage | No of Days in a month | Monthly consumption | |
|--------------|-------------------|--------------------|------------------|-------|---------|-----|---------|----------------|-----------------------|---------------------|------|
| | | | | | | No | watt | hrs | days | kWh/day | |
| Ground floor | | Staircase | LED | 1x20W | EC | 1 | 20 | 1 | 25 | 0.50 | |
| | | Parking | LED | 1x12W | EC | 11 | 12 | 5 | 25 | 16.50 | |
| | | Street light | LED | 1x30W | EC | 4 | 40 | 11 | 25 | 44.00 | |
| | 1 | Counselling cell | LED | 1x20W | EC | 2 | 20 | 0.25 | 25 | 0.25 | |
| | 2 | Room 1 | LED | 1x20W | EC | 2 | 25 | 0.25 | 25 | 0.31 | |
| | 3 | Ladies staff room | LED | 1x20W | EC | 1 | 20 | 0.25 | 25 | 0.13 | |
| | 4 | Gymkhana | LED | 1x20W | EC | 4 | 20 | 0.25 | 25 | 0.50 | |
| Ground floor | | | FTL | 1x36W | MC | 1 | 40 | 0.25 | 25 | 0.25 | |
| | 5 | Store room | LED | 1x20W | EC | 1 | 20 | 0.1 | 25 | 0.05 | |
| 1st Floor | 109 | College office | LED | 2x20W | EC | 2 | 20 | 8 | 25 | 8.00 | |
| | | | LED | 1x20W | EC | 1 | 20 | 8 | 25 | 4.00 | |
| | | | FTL | 2x36W | EC | 2 | 36 | 8 | 25 | 14.40 | |
| | | Cash room | FTL | 2x36W | EC | 2 | 36 | 8 | 25 | 14.40 | |
| 1st Floor | 108 | Faculty room | FTL | 1x36W | EC | 1 | 36 | 7 | 25 | 6.30 | |
| | | | FTL | 1x40W | EC | 1 | 40 | 7 | 25 | 7.00 | |
| | 107 | Examination office | LED | 2*20W | EC | 2 | 20 | 7 | 25 | 7.00 | |
| | | | Principal office | FTL | 2x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| | | | | FTL | 1x36W | EC | 1 | 36 | 0.25 | 25 | 0.23 |
| | | LED | 1x12W | EC | 2 | 12 | 0.25 | 25 | 0.15 | | |
| | 1st floor passage | FTL | 1x36W | EC | 4 | 36 | 8 | 25 | 28.80 | | |

| | | | | | | | | | |
|------------------|--------------------|-----|-------|----|---|----|-----|----|-------|
| 101 | BA LLB-I-A | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| | | LED | 1x20W | EC | 1 | 20 | 5 | 25 | 2.50 |
| 102 | BA LLB-I-B | FTL | 1x36W | MC | 1 | 40 | 5 | 25 | 5.00 |
| | | LED | 1x20W | EC | 3 | 20 | 5 | 25 | 7.50 |
| 103 | BA LLB-II | FTL | 1x36W | MC | 1 | 40 | 5 | 25 | 5.00 |
| | | LED | 1x20W | EC | 3 | 20 | 5 | 25 | 7.50 |
| 104 | Women cell | FTL | 1x36W | EC | 1 | 36 | 0.1 | 25 | 0.09 |
| 105 | Ladies common cell | FTL | 1x36W | EC | 1 | 36 | 0.1 | 25 | 0.09 |
| | Gent's toilet | LED | 1x20W | EC | 2 | 20 | 7 | 25 | 7.00 |
| | Ladies' toilet | LED | 1x20W | EC | 2 | 20 | 7 | 25 | 7.00 |
| 2nd Floor | Library | FTL | 1x36W | EC | 4 | 36 | 8 | 25 | 28.80 |
| | | LED | 1x20W | EC | 4 | 20 | 8 | 25 | 16.00 |
| | | LED | 1x12W | EC | 2 | 12 | 5 | 25 | 3.00 |
| | Reference library | FTL | 1x36W | EC | 2 | 36 | 1 | 25 | 1.80 |
| | | FTL | 1x40W | EC | 1 | 40 | 1 | 25 | 1.00 |
| | | LED | 1*20W | EC | 3 | 20 | 1 | 25 | 1.50 |
| | Computer room | LED | 1x12W | EC | 2 | 12 | 1 | 25 | 0.60 |
| | 2nd floor passage | LED | 1x12W | EC | 3 | 12 | 8 | 25 | 7.20 |
| 201 | LLB-1-A | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| | | LED | 1x20W | EC | 3 | 20 | 5 | 25 | 7.50 |
| 202 | LLB-1-B | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| | | FTL | 1x40W | EC | 1 | 40 | 5 | 25 | 5.00 |
| | | LED | 1*20W | EC | 3 | 20 | 5 | 25 | 7.50 |
| 203 | LLB-1-C | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| | | FTL | 1x40W | EC | 2 | 40 | 5 | 25 | 10.00 |
| | | LED | 1*20W | EC | 2 | 20 | 5 | 25 | 5.00 |

| | | | | | | | | | | |
|------------------|-----|------------------|---------|-------|----|----|-----|------|----|-------|
| | 206 | Research cell | LED | 1x12W | EC | 2 | 12 | 5 | 25 | 3.00 |
| | | Gent's toilet | FTL | 1x36W | EC | 1 | 36 | 7 | 25 | 6.30 |
| | | | LED | 1x20W | EC | 1 | 20 | 7 | 25 | 3.50 |
| | | Ladies' toilet | LED | 1x20W | EC | 2 | 20 | 7 | 25 | 7.00 |
| 3rd Floor | 301 | Moot court hall | FTL | 1x40W | MC | 1 | 45 | 0.25 | 25 | 0.28 |
| | | | FTL | 1x40W | EC | 1 | 40 | 0.25 | 25 | 0.25 |
| | | | LED | 1x20W | EC | 1 | 20 | 0.25 | 25 | 0.13 |
| | 302 | BA LLB-III | FTL | 1x40W | EC | 2 | 40 | 5 | 25 | 10.00 |
| | | | LED | 1x20W | EC | 3 | 20 | 5 | 25 | 7.50 |
| | 303 | BA LLB-IV | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| | | | LED | 1x20W | EC | 3 | 20 | 5 | 25 | 7.50 |
| | 304 | Record room II | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| | 305 | Seminar hall | LED | 1x20W | EC | 12 | 20 | 0.5 | 25 | 3.00 |
| | | | Halogen | 250W | MC | 2 | 250 | 0.05 | 25 | 0.63 |
| | 306 | LLB I-D | LED | 1x20W | EC | 4 | 20 | 5 | 25 | 10.00 |
| | | LLM staff room | LED | 1x20W | EC | 1 | 20 | 5 | 25 | 2.50 |
| | | LLM staff toilet | FTL | 1x36W | EC | 1 | 36 | 0.25 | 25 | 0.23 |
| | | Gent's toilet | FTL | 1x36W | MC | 1 | 40 | 0.25 | 25 | 0.25 |
| | | | FTL | 1x40W | MC | 1 | 45 | 0.25 | 25 | 0.28 |
| | | Ladies' toilet | FTL | 1x36W | MC | 1 | 40 | 0.25 | 25 | 0.25 |
| | | | FTL | 1x40W | MC | 1 | 45 | 0.25 | 25 | 0.28 |
| 4th Floor | 401 | LLB II-A | FTL | 1x36W | EC | 1 | 36 | 2 | 25 | 1.80 |
| | 402 | LLB II-B | FTL | 1x36W | EC | 1 | 36 | 2 | 25 | 1.80 |
| | 403 | LLB II-C | FTL | 1x36W | EC | 1 | 36 | 2 | 25 | 1.80 |
| | 404 | Record room III | FTL | 1x36W | EC | 1 | 36 | 0.1 | 25 | 0.09 |
| | | Gent's toilet | LED | 1x20W | EC | 2 | 20 | 0.1 | 25 | 0.10 |

| | | | | | | | | |
|-------------------|-----|-------|----|---|----|-----|----|---------------|
| Ladies' toilet | LED | 1x20W | EC | 2 | 20 | 0.1 | 25 | 0.10 |
| 4th floor passage | LED | 1x12W | EC | 2 | 12 | 0.1 | 25 | 0.06 |
| Staircase | LED | 1x20W | EC | 3 | 20 | 0.1 | 25 | 0.15 |
| 2346.00 | | | | | | | | 407.61 |

ENERGY SAVING MEASURES

| Floor | Room | Name | Light Type | Qty | Watt | Mthly kWh | Change | New Qty | New mthly kWh | Mthly saving kWh | Mthly saving Rs | Total inv Rs | Payback period months | |
|---------------------|------|-------------------|------------|-------|------|-----------|--------|-----------|---------------|------------------|-----------------|--------------|-----------------------|--------|
| | | | | no | W | kWh | | No | kWh | kWh | Rs | Rs | months | |
| Ground floor | | | FTL | 1x36W | 1 | 40 | 0.25 | LED-1x18W | 1 | 0.11 | 0.14 | 1.38 | 250 | 181.82 |
| | | | FTL | 2x36W | 2 | 36 | 14.4 | LED-1x18W | 1 | 3.60 | 10.80 | 108.00 | 250 | 2.31 |
| | | Cash room | FTL | 2x36W | 2 | 36 | 14.4 | LED-1x18W | 1 | 3.60 | 10.80 | 108.00 | 250 | 2.31 |
| 1st Floor | 108 | Faculty room | FTL | 1x36W | 1 | 36 | 6.3 | LED-1x18W | 1 | 3.15 | 3.15 | 31.50 | 250 | 7.94 |
| | | | FTL | 1x40W | 1 | 40 | 7 | LED-1x18W | 1 | 3.15 | 3.85 | 38.50 | 250 | 6.49 |
| | | Principal office | FTL | 2x36W | 2 | 36 | 9 | LED-1x18W | 1 | 2.25 | 6.75 | 67.50 | 250 | 3.70 |
| | | | FTL | 1x36W | 1 | 36 | 0.225 | LED-1x18W | 1 | 0.11 | 0.11 | 1.13 | 250 | 222.22 |
| | | 1st floor passage | FTL | 1x36W | 4 | 36 | 28.8 | LED-1x18W | 4 | 14.40 | 14.40 | 144.00 | 1000 | 6.94 |
| | 101 | BA LLB-I-A | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 2 | 4.50 | 4.50 | 45.00 | 500 | 11.11 |
| | 102 | BA LLB-I- | FTL | 1x36W | 1 | 40 | 5 | LED-1x18W | 1 | 2.25 | 2.75 | 27.50 | 250 | 9.09 |

| B | | | | | | | | | | | | | | |
|------------------|-----|--------------------|-----|-------|---|----|---------|-----------|---|-------|-------|--------|------|--------|
| | 103 | BA LLB-II | FTL | 1x36W | 1 | 40 | 5 | LED-1x18W | 1 | 2.25 | 2.75 | 27.50 | 250 | 9.09 |
| | 104 | Women cell | FTL | 1x36W | 1 | 36 | 0.09 | LED-1x18W | 1 | 0.05 | 0.05 | 0.45 | 250 | 555.56 |
| | 105 | Ladies common cell | FTL | 1x36W | 1 | 36 | 0.09 | LED-1x18W | 1 | 0.05 | 0.05 | 0.45 | 250 | 555.56 |
| 2nd Floor | | Library | FTL | 1x36W | 4 | 36 | 28.8 | LED-1x18W | 4 | 14.40 | 14.40 | 144.00 | 1000 | 6.94 |
| | | Reference library | FTL | 1x36W | 2 | 36 | 1.8 | LED-1x18W | 2 | 0.90 | 0.90 | 9.00 | 500 | 55.56 |
| | | | FTL | 1x40W | 1 | 40 | 1 | LED-1x18W | 1 | 0.45 | 0.55 | 5.50 | 250 | 45.45 |
| | 201 | LLB-1-A | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 2 | 4.50 | 4.50 | 45.00 | 500 | 11.11 |
| | 202 | LLB-1-B | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 1 | 2.25 | 2.25 | 22.50 | 250 | 11.11 |
| | | | FTL | 1x40W | 1 | 40 | 5 | LED-1x18W | 1 | 2.25 | 2.75 | 27.50 | 250 | 9.09 |
| | 203 | LLB-1-C | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 1 | 2.25 | 2.25 | 22.50 | 250 | 11.11 |
| | | | FTL | 1x40W | 2 | 40 | 10 | LED-1x18W | 2 | 4.50 | 5.50 | 55.00 | 500 | 9.09 |
| | | Gent's toilet | FTL | 1x36W | 1 | 36 | 6.3 | LED-1x18W | 1 | 3.15 | 3.15 | 31.50 | 250 | 7.94 |
| 3rd Floor | 301 | Moot court hall | FTL | 1x40W | 1 | 45 | 0.28125 | LED-1x18W | 1 | 0.11 | 0.17 | 1.69 | 250 | 148.15 |
| | | | FTL | 1x40W | 1 | 40 | 0.25 | LED-1x18W | 1 | 0.11 | 0.14 | 1.38 | 250 | 181.82 |
| | 302 | BA LLB-III | FTL | 1x40W | 2 | 40 | 10 | LED-1x18W | 2 | 4.50 | 5.50 | 55.00 | 500 | 9.09 |
| | 303 | BA LLB-IV | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 2 | 4.50 | 4.50 | 45.00 | 500 | 11.11 |
| | 304 | Record room II | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 1 | 2.25 | 2.25 | 22.50 | 250 | 11.11 |
| | | LLM staff toilet | FTL | 1x36W | 1 | 36 | 0.225 | LED-1x18W | 1 | 0.11 | 0.11 | 1.13 | 250 | 222.22 |

| | | | | | | | | | | | | | | |
|------------------|-----|-----------------|-----|-------|---|----|---------------|-----------|---|--------------|---------------|----------------|--------------|-------------|
| | | Gent's toilet | FTL | 1x36W | 1 | 40 | 0.25 | LED-1x18W | 1 | 0.11 | 0.14 | 1.38 | 250 | 181.82 |
| | | | FTL | 1x40W | 1 | 45 | 0.28125 | LED-1x18W | 1 | 0.11 | 0.17 | 1.69 | 250 | 148.15 |
| | | Ladies' toilet | FTL | 1x36W | 1 | 40 | 0.25 | LED-1x18W | 1 | 0.11 | 0.14 | 1.38 | 250 | 181.82 |
| | | | FTL | 1x40W | 1 | 45 | 0.28125 | LED-1x18W | 1 | 0.11 | 0.17 | 1.69 | 250 | 148.15 |
| 4th Floor | 401 | LLB II-A | FTL | 1x36W | 1 | 36 | 1.8 | LED-1x18W | 1 | 0.90 | 0.90 | 9.00 | 250 | 27.78 |
| | 402 | LLB II-B | FTL | 1x36W | 1 | 36 | 1.8 | LED-1x18W | 1 | 0.90 | 0.90 | 9.00 | 250 | 27.78 |
| | 403 | LLB II-C | FTL | 1x36W | 1 | 36 | 1.8 | LED-1x18W | 1 | 0.90 | 0.90 | 9.00 | 250 | 27.78 |
| | 404 | Record room III | FTL | 1x36W | 1 | 36 | 0.09 | LED-1x18W | 1 | 0.05 | 0.05 | 0.45 | 250 | 555.56 |
| | | | | | | | 216.89 | | | 96.48 | 120.41 | 1204.10 | 12000 | 9.97 |


| Particulars | | |
|-------------------------|--------|-----------|
| Monthly consumption | 216.89 | kWh/month |
| New monthly consumption | 96.48 | kWh/month |
| New monthly saving | 120.41 | kWh/month |
| New monthly saving | 1204.1 | Rs/month |
| Total Investment | 12000 | Rs |
| Payback period | 9.97 | months |

2. BOY'S HOSTEL

OBSERVATION

Boy's hostel has installed almost all old conventional lightings. Most of the lightings are FTL 1x36W

| Type | Quantity | kW load |
|-------------------------|-----------|-------------|
| LED lights | 0 | 0.00 |
| Old conventional lights | 76 | 2.02 |
| Total | 76 | 2.02 |



PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM

| Floor | Room | Name | Light Type | Type | Ballast | Qty | Wattage | Hours of usage | No of Days in a month | Monthly consumption |
|--------------|------|---------|------------|-------|---------|-----|---------|----------------|-----------------------|---------------------|
| | | | | | | No | watt | hrs | days | kWh/day |
| Ground floor | 1 | Room 1 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 2 | Room 2 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 3 | Room 3 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 4 | Room 4 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 5 | Room 5 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 6 | Room 6 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 7 | Room 7 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 8 | Room 8 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 9 | Room 9 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 10 | Room 10 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 11 | Room 11 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 12 | Room 12 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 13 | Room 13 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 14 | Room 14 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 15 | Room 15 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 16 | Room 16 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 17 | Room 17 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 18 | Room 18 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 19 | Room 19 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 20 | Room 20 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 21 | Room 21 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |

| | | | | | | | | | | |
|------------------|-------|------------------|-----|-------|----|---|----|----|----|-------|
| | 22 | Room 22 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 23 | Room 23 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | | Bathroom 1 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| 1st Floor | 24 | Room 24 | FTL | 1x36W | EC | 2 | 36 | 11 | 25 | 19.80 |
| | 25 | Room 25 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 26 | Room 26 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 27 | Room 27 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 28 | Room 28 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 29 | Room 29 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 30 | Room 30 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 31 | Room 31 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 32 | Room 32 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 33 | Room 33 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 34 | Room 34 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 35 | Room 35 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 36 | Room 36 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 37 | Room 37 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 38 | Room 38 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 39 | Room 39 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 40 | Room 40 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 41 | Room 41 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 42 | Room 42 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 43 | Room 43 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 44 | Room 44 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 45 | Room 45 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | 46/47 | ITI class room 1 | FTL | 1x36W | EC | 2 | 36 | 4 | 25 | 7.20 |

| | | | | | | | | | |
|------------------|------------------|-----|-------|----|-----------|-------------|----|----|---------------|
| 48/49 | ITI class room 2 | FTL | 1x36W | EC | 2 | 36 | 4 | 25 | 7.20 |
| 50/51 | ITI class room 3 | FTL | 1x36W | EC | 3 | 36 | 4 | 25 | 10.80 |
| 52 | Room 46 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| 53 | Room 47 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| 54 | Room 48 | FTL | 1x36W | EC | 1 | 36 | 6 | 25 | 5.40 |
| | Hall | FTL | 1x36W | EC | 14 | 36 | 6 | 25 | 75.60 |
| | Bathroom 1 | FTL | 1x36W | EC | 1 | 36 | 11 | 25 | 9.90 |
| 1st Floor | ITI office | FTL | 1x36W | EC | 3 | 36 | 6 | 25 | 16.20 |
| | | | | | 75 | 1980 | | | 405.90 |

ENERGY SAVING MEASURES

| Room | Name | Light Type | Qty | Watt | Mthly kWh | Change | New watt | New Qty | New mthly kWh | Mthly saving | Mthly saving | Total inv | Payback period |
|------|--------|------------|-----|------|-----------|-----------|----------|---------|---------------|--------------|--------------|-----------|----------------|
| | | | No | W | kWh | | W | No | kWh | kWh | Rs | Rs | months |
| 1 | Room 1 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 2 | Room 2 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 3 | Room 3 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 4 | Room 4 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 5 | Room 5 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 6 | Room 6 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 7 | Room 7 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 8 | Room 8 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 9 | Room 9 | FTL 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |

| | | | | | | | | | | | | | | |
|-----------|---------------|-----|-------|---|----|------|-----------|----|---|------|------|--------|-----|-------|
| 10 | Room 10 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 11 | Room 11 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 12 | Room 12 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 13 | Room 13 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 14 | Room 14 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 15 | Room 15 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 16 | Room 16 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 17 | Room 17 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 18 | Room 18 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 19 | Room 19 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 20 | Room 20 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 21 | Room 21 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 22 | Room 22 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 23 | Room 23 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| | Bathroom 1 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 19 | 1 | 2.85 | 2.55 | 26.83 | 300 | 11.18 |
| 24 | Room 24 | FTL | 1x36W | 2 | 36 | 19.8 | LED-1x18W | 18 | 2 | 9.9 | 9.9 | 104.15 | 600 | 5.76 |
| 25 | Room 25 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 26 | Room 26 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 27 | Room 27 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 28 | Room 28 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 29 | Room 29 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 30 | Room 30 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 31 | Room 31 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |

| | | | | | | | | | | | | | | |
|--------------|------------------|-----|-------|----|----|------|-----------|----|----|------|------|--------|------|-------|
| 32 | Room 32 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 33 | Room 33 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 34 | Room 34 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 35 | Room 35 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 36 | Room 36 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 37 | Room 37 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 38 | Room 38 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 39 | Room 39 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 40 | Room 40 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 41 | Room 41 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 42 | Room 42 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 43 | Room 43 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 44 | Room 44 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 45 | Room 45 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 46/47 | ITI class room 1 | FTL | 1x36W | 2 | 36 | 7.2 | LED-1x18W | 18 | 2 | 3.6 | 3.6 | 37.87 | 600 | 15.84 |
| 48/49 | ITI class room 2 | FTL | 1x36W | 2 | 36 | 7.2 | LED-1x18W | 18 | 2 | 3.6 | 3.6 | 37.87 | 600 | 15.84 |
| 50/51 | ITI class room 3 | FTL | 1x36W | 3 | 36 | 10.8 | LED-1x18W | 18 | 3 | 5.4 | 5.4 | 56.81 | 900 | 15.84 |
| 52 | Room 46 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 53 | Room 47 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| 54 | Room 48 | FTL | 1x36W | 1 | 36 | 5.4 | LED-1x18W | 18 | 1 | 2.7 | 2.7 | 28.40 | 300 | 10.56 |
| | Hall | FTL | 1x36W | 14 | 36 | 75.6 | LED-1x18W | 18 | 14 | 37.8 | 37.8 | 397.66 | 4200 | 10.56 |
| | Bathroom 1 | FTL | 1x36W | 1 | 36 | 9.9 | LED-1x18W | 18 | 1 | 4.95 | 4.95 | 52.07 | 300 | 5.76 |

| | | | | | | | | | | | | | |
|------------|-----|-------|-----------|-------------|--------------|-----------|----|-----------|--------------|--------------|----------------|--------------|--------------|
| ITI office | FTL | 1x36W | 3 | 36 | 16.2 | LED-1x18W | 18 | 3 | 8.1 | 8.1 | 85.21 | 900 | 10.56 |
| | | | 75 | 1980 | 405.9 | | | 75 | 203.1 | 202.8 | 2133.46 | 22500 | 10.69 |


| Particulars | | |
|-------------------------|--------------|---------------|
| Monthly consumption | 405.90 | kWh/month |
| New monthly consumption | 203.10 | kWh/month |
| New monthly saving | 202.80 | kWh/month |
| New monthly saving | 2133.46 | Rs/month |
| Total Investment | 22500 | Rs |
| Payback period | 10.55 | months |

3. GIRL'S HOSTEL

OBSERVATION

In girl's hostel still most of the room lightings are old conventional FTL 1x36W and CFL . At few places new energy efficient LED 1x20W lightings and street lights are used.

| Type | Quantity | kW load | % load |
|-------------------------|-----------|-------------|------------|
| LED lights | 12 | 0.73 | 22.64 |
| Old conventional lights | 41 | 1.37 | 77.36 |
| Total | 53 | 2.10 | 100 |



PERFORMANCE ASSESSMENT OF LIGHTING SYSTEM

| Room | Name | Light Type | Type | Ballast | Qty | Wattage | Hours of usage | No of Days in a month | Monthly consumption |
|------|---------|------------|-------|---------|-----|---------|----------------|-----------------------|---------------------|
| | | | | | No | watt | hrs | days | kWh/day |
| 1 | Room 1 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 2 | Room 2 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 3 | Room 3 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 4 | Room 4 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 5 | Room 5 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 6 | Room 6 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 7 | Room 7 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 8 | Room 8 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 9 | Room 9 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 10 | Room 10 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 11 | Room 11 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 12 | Room 12 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 13 | Room 13 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 14 | Room 14 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 15 | Room 15 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 16 | Room 16 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 17 | Room 17 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 18 | Room 18 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 19 | Room 19 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 20 | Room 20 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 21 | Room 21 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |

| | | | | | | | | | |
|-------------|-------------------|-----|-------|----|---|----|---|----|---------------|
| 22 | Room 22 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 23 | Room 23 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 24 | Room 24 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 25 | Room 25 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 26 | Room 26 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 27 | Room 27 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 28 | Room 28 | FTL | 1x36W | EC | 1 | 36 | 5 | 25 | 4.50 |
| 29 | Room 29 | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| 30 | Room 30 | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| 31 | Room 31 | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| 32 | Room 32 | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| | Passage ground | FTL | 1x36W | EC | 2 | 36 | 7 | 25 | 12.60 |
| | | LED | 1x20W | EC | 1 | 20 | 7 | 26 | 3.64 |
| | Passage 1st floor | FTL | 1x36W | EC | 3 | 36 | 7 | 25 | 18.90 |
| | Passage 2nd floor | FTL | 1x36W | EC | 3 | 36 | 7 | 25 | 18.90 |
| | Passage 3rd floor | FTL | 1x36W | EC | 3 | 36 | 7 | 25 | 18.90 |
| | Passage 4th floor | FTL | 1x36W | EC | 3 | 36 | 7 | 25 | 18.90 |
| | Mess | FTL | 1x36W | EC | 2 | 36 | 5 | 25 | 9.00 |
| | | LED | 1x20W | EC | 5 | 20 | 5 | 25 | 12.50 |
| | | LED | 1x12W | EC | 3 | 12 | 5 | 25 | 4.50 |
| | | CFL | 1x18W | EC | 1 | 18 | 1 | 25 | 0.45 |
| | Back outdoor room | FTL | 1x36W | EC | 2 | 36 | 3 | 25 | 5.40 |
| | | LED | 1x20W | EC | 1 | 20 | 7 | 25 | 3.50 |
| | | LED | 1x50W | EC | 2 | 50 | 2 | 25 | 5.00 |
| | Street light | FTL | 1x36W | EC | 5 | 36 | 7 | 25 | 31.50 |
| 1580 | | | | | | | | | 325.69 |

ENERGY SAVING MEASURES

| Room | Name | Light Type | Qty | Watts | Monthly kWh | Change | New watts | New used Qty | New mthly kWh | Mthly saving | Mthly saving | Total inv | Payback period |
|------|---------|------------|-----|-------|-------------|-----------|-----------|--------------|---------------|--------------|--------------|-----------|----------------|
| | | | No | W | kWh | | W | No | kWh | kWh | Rs | Rs | months |
| 1 | Room 1 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 2 | Room 2 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 3 | Room 3 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 4 | Room 4 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 5 | Room 5 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 6 | Room 6 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 7 | Room 7 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 8 | Room 8 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 9 | Room 9 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 10 | Room 10 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 11 | Room 11 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 12 | Room 12 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 13 | Room 13 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 14 | Room 14 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 15 | Room 15 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 16 | Room 16 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 17 | Room 17 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 18 | Room 18 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 19 | Room 19 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 20 | Room 20 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 21 | Room 21 | FTL 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |

| | | | | | | | | | | | | | | |
|-----------|-------------------|-----|-------|---|----|---------------|-----------|----|---|---------------|---------------|----------------|--------------|-------------|
| 22 | Room 22 | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 23 | Room 23 | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 24 | Room 24 | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 25 | Room 25 | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 26 | Room 26 | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 27 | Room 27 | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 28 | Room 28 | FTL | 1x36W | 1 | 36 | 4.5 | LED-1x18W | 18 | 1 | 2.25 | 2.25 | 34.02 | 300 | 8.81 |
| 29 | Room 29 | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 18 | 2 | 4.5 | 4.5 | 68.04 | 600 | 8.81 |
| 30 | Room 30 | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 18 | 2 | 4.5 | 4.5 | 68.04 | 600 | 8.81 |
| 31 | Room 31 | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 18 | 2 | 4.5 | 4.5 | 68.04 | 600 | 8.81 |
| 32 | Room 32 | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 18 | 2 | 4.5 | 4.5 | 68.04 | 600 | 8.81 |
| | Passage ground | FTL | 1x36W | 2 | 36 | 12.6 | LED-1x18W | 18 | 2 | 6.3 | 6.3 | 95.256 | 600 | 6.29 |
| | Passage 1st floor | FTL | 1x36W | 3 | 36 | 18.9 | LED-1x18W | 18 | 3 | 9.45 | 9.45 | 142.884 | 900 | 6.29 |
| | Passage 2nd floor | FTL | 1x36W | 3 | 36 | 18.9 | LED-1x18W | 18 | 3 | 9.45 | 9.45 | 142.884 | 900 | 6.29 |
| | Passage 3rd floor | FTL | 1x36W | 3 | 36 | 18.9 | LED-1x18W | 18 | 3 | 9.45 | 9.45 | 142.884 | 900 | 6.29 |
| | Passage 4th floor | FTL | 1x36W | 3 | 36 | 18.9 | LED-1x18W | 18 | 3 | 9.45 | 9.45 | 142.884 | 900 | 6.29 |
| | Mess | FTL | 1x36W | 2 | 36 | 9 | LED-1x18W | 18 | 2 | 4.5 | 4.5 | 68.04 | 600 | 8.81 |
| | | CFL | 1x18W | 1 | 18 | 0.45 | LED-1x5W | 5 | 1 | 0.125 | 0.325 | 4.914 | 300 | 61.05 |
| | Back outdoor room | FTL | 1x36W | 2 | 36 | 5.4 | LED-1x18W | 2 | 2 | 0.3 | 5.1 | 77.112 | 600 | 7.78 |
| | | LED | 1x50W | 2 | 50 | 5 | LED-1x20W | 20 | 2 | 2 | 3 | 45.36 | 600 | 13.22 |
| | Street light | FTL | 1x36W | 5 | 36 | 31.5 | LED-1x20W | 20 | 5 | 17.5 | 14 | 211.68 | 1500 | 7.08 |
| | | | | | | 301.55 | | | | 149.53 | 152.03 | 2298.62 | 18600 | 8.09 |

| Particulars | | |
|-------------------------|-------------|---------------|
| Monthly consumption | 301.55 | kWh/month |
| New monthly consumption | 149.53 | kWh/month |
| New monthly saving | 152.02 | kWh/month |
| New monthly saving | 2298.54 | Rs/month |
| Total Investment | 18600 | Rs |
| Payback period | 8.09 | months |

ENERGY PERFORMANCE ASSESSMENT OF FAN

1. MAIN COLLEGE BUILDING

OBSERVATION

College has installed old conventional induction motor fan which consumes 65W at full speed. It is recommended that replace old fan which are operated maximum usage per day with new energy efficient fan which consumes 28W at full speed.

ENERGY SAVING MEASURES

| Floor | Room | Name | Qty | Watt | Hours of usage | No of Days in a month | Mthly kWh | New change watt | New mthly kWh | Mthly saving | Mthly saving | Total inv | Payback period |
|-----------|------|--------------------|-----|------|----------------|-----------------------|-----------|-----------------|---------------|--------------|--------------|-----------|----------------|
| | | | No | W | Hrs | Days | kWh | W | kWh | kWh | Rs | Rs | months |
| 1st Floor | 109 | College office | 4 | 65 | 8 | 25 | 52 | 28 | 22.4 | 29.6 | 296 | 9600 | 32.43 |
| | | Cash room | 1 | 65 | 5 | 25 | 8.125 | 28 | 3.5 | 4.625 | 46.25 | 2400 | 51.89 |
| | 108 | Faculty room | 2 | 65 | 3 | 25 | 9.75 | 28 | 4.2 | 5.55 | 55.5 | 4800 | 86.49 |
| | 107 | Examination office | 2 | 65 | 3 | 25 | 9.75 | 28 | 4.2 | 5.55 | 55.5 | 4800 | 86.49 |
| | 101 | BA LLB-I-A | 4 | 65 | 3 | 25 | 19.5 | 28 | 8.4 | 11.1 | 111 | 9600 | 86.49 |
| | 102 | BA LLB-I-B | 3 | 65 | 3 | 25 | 14.625 | 28 | 6.3 | 8.325 | 83.25 | 7200 | 86.49 |
| | 103 | BA LLB-II | 4 | 65 | 3 | 25 | 19.5 | 28 | 8.4 | 11.1 | 111 | 9600 | 86.49 |
| 2nd Floor | | Library | 8 | 65 | 8 | 25 | 104 | 28 | 44.8 | 59.2 | 592 | 19200 | 32.43 |
| | 201 | LLB-1-A | 4 | 65 | 3 | 25 | 19.5 | 28 | 8.4 | 11.1 | 111 | 9600 | 86.49 |
| | 202 | LLB-1-B | 3 | 65 | 3 | 25 | 14.625 | 28 | 6.3 | 8.325 | 83.25 | 7200 | 86.49 |

| | | | | | | | | | | | | |
|-----|----------------|-----------|----|---|----|---------------|----|---------------|--------------|---------------|---------------|--------------|
| 203 | LLB-1-C | 4 | 65 | 3 | 25 | 19.5 | 28 | 8.4 | 11.1 | 111 | 9600 | 86.49 |
| 206 | Research cell | 2 | 65 | 3 | 26 | 10.14 | 28 | 4.368 | 5.772 | 57.72 | 4800 | 83.16 |
| 302 | BA LLB-III | 3 | 65 | 3 | 33 | 19.305 | 28 | 8.316 | 10.989 | 109.89 | 7200 | 65.52 |
| 303 | BA LLB-IV | 4 | 65 | 3 | 35 | 27.3 | 28 | 11.76 | 15.54 | 155.4 | 9600 | 61.78 |
| 306 | LLB I-D | 3 | 65 | 3 | 40 | 23.4 | 28 | 10.08 | 13.32 | 133.2 | 7200 | 54.05 |
| | LLM staff room | 2 | 65 | 3 | 41 | 15.99 | 28 | 6.888 | 9.102 | 91.02 | 4800 | 52.74 |
| | | 60 | | | | 387.01 | | 166.71 | 220.3 | 1667.2 | 127200 | 76.30 |

| Particulars | | |
|--|--------------|---------------|
| Monthly consumption of all fans | 441.83 | kWh/month |
| Total fans | 92.00 | nos |
| Fans to be replaced with new energy efficient fans | 60.00 | nos |
| Monthly consumption of 60 fans | 387.01 | kWh/month |
| New monthly consumption | 166.71 | kWh/month |
| New monthly saving | 220.30 | kWh/month |
| New monthly saving | 2203 | Rs/month |
| Total Investment | 127200 | Rs |
| Payback period | 57.74 | months |

2. BOY'S HOSTEL

ENERGY SAVING MEASURES

| Floor | Room | Name | Qty | watt | Hours of usage | No of Days in a month | Mthly kWh | change watt | New mthly kWh | Mthly saving | Mthly saving | Total inv | Payback period |
|--------------|------|---------|-----|------|----------------|-----------------------|-----------|-------------|---------------|--------------|--------------|-----------|----------------|
| | | | No | watt | hrs | days | kWh | watt | kWh | kWh | Rs | Rs | months |
| Ground floor | 1 | Room 1 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 2 | Room 2 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 3 | Room 3 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 4 | Room 4 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 5 | Room 5 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 6 | Room 6 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 7 | Room 7 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 8 | Room 8 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 9 | Room 9 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 10 | Room 10 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 11 | Room 11 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 12 | Room 12 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 13 | Room 13 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 14 | Room 14 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 15 | Room 15 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 16 | Room 16 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 17 | Room 17 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 18 | Room 18 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |

| | | | | | | | | | | | | | |
|------------------|----|---------|---|----|---|----|------|----|-----|------|--------|------|-------|
| | 19 | Room 19 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 20 | Room 20 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 21 | Room 21 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 22 | Room 22 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 23 | Room 23 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| 1st Floor | 24 | Room 24 | 2 | 65 | 6 | 25 | 19.5 | 28 | 8.4 | 11.1 | 116.77 | 4800 | 41.11 |
| | 25 | Room 25 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 26 | Room 26 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 27 | Room 27 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 28 | Room 28 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 29 | Room 29 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 30 | Room 30 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 31 | Room 31 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 32 | Room 32 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 33 | Room 33 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 34 | Room 34 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 35 | Room 35 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 36 | Room 36 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 37 | Room 37 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 38 | Room 38 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 39 | Room 39 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 40 | Room 40 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 41 | Room 41 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 42 | Room 42 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 43 | Room 43 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 44 | Room 44 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | 45 | Room 45 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |

| | | | | | | | | | | | | |
|------------------|------------|-----------|-------------|---|----|--------------|----|--------------|--------------|----------------|---------------|--------------|
| 52 | Room 46 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | Room 50 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | Room 51 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | Room 52 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 58.39 | 2400 | 41.11 |
| | Hall | 17 | 36 | 6 | 25 | 91.8 | 28 | 71.4 | 20.4 | 214.61 | 40800 | 190.11 |
| 1st Floor | ITI office | 2 | 36 | 6 | 25 | 10.8 | 28 | 8.4 | 2.4 | 25.25 | 4800 | 190.11 |
| | | 69 | 3452 | | | 590.1 | | 289.8 | 300.3 | 3159.16 | 165600 | 52.42 |

| Particulars | | |
|--|--------------|---------------|
| Monthly consumption of all fans | 619.35 | kWh/month |
| Total fans | 75 | nos |
| Fans to be replaced with new energy efficient fans | 69 | nos |
| Monthly consumption of 69 fans | 590.10 | kWh/month |
| New monthly consumption | 289.8 | kWh/month |
| New monthly saving | 300.30 | kWh/month |
| New monthly saving | 3159.16 | Rs/month |
| Total Investment | 165600 | Rs |
| Payback period | 52.42 | months |

3. GIRL'S HOSTEL

ENERGY SAVING MEASURES

| Room | Name | Qty | Watt | Hours of usage | No of Days in a month | Mthly kWh | Change watt | New mthly kWh | Mthly saving | Mthly saving | Total inv | Payback period |
|------|---------------|-----|------|----------------|-----------------------|-----------|-------------|---------------|--------------|--------------|-----------|----------------|
| | Girl's hostel | No | watt | hrs | days | kWh | watt | kWh | kWh | Rs | Rs | months |
| 1 | Room 1 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 2 | Room 2 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 3 | Room 3 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 4 | Room 4 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 5 | Room 5 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 6 | Room 6 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 7 | Room 7 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 8 | Room 8 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 9 | Room 9 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 10 | Room 10 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 11 | Room 11 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 12 | Room 12 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 13 | Room 13 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 14 | Room 14 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 15 | Room 15 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 16 | Room 16 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 17 | Room 17 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 18 | Room 18 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |

| | | | | | | | | | | | | |
|-----------|---------|-----------|-------------|---|----|---------------|----|---------------|---------------|----------------|--------------|--------------|
| 19 | Room 19 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 20 | Room 20 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 21 | Room 21 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 22 | Room 22 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 23 | Room 23 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 24 | Room 24 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 25 | Room 25 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 26 | Room 26 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 27 | Room 27 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 28 | Room 28 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 29 | Room 29 | 1 | 65 | 6 | 25 | 9.75 | 28 | 4.2 | 5.55 | 83.92 | 2400 | 28.60 |
| 30 | Room 30 | 2 | 65 | 6 | 25 | 19.5 | 28 | 8.4 | 11.1 | 167.83 | 4800 | 28.60 |
| 31 | Room 31 | 2 | 65 | 6 | 25 | 19.5 | 28 | 8.4 | 11.1 | 167.83 | 4800 | 28.60 |
| 32 | Room 32 | 2 | 65 | 6 | 25 | 19.5 | 28 | 8.4 | 11.1 | 167.83 | 4800 | 28.60 |
| | | 41 | 2275 | | | 341.25 | | 147.00 | 194.25 | 2937.06 | 84000 | 28.60 |

| Particulars | | |
|--|--------------|---------------|
| Monthly consumption of all fans | 365.64 | kWh/month |
| Total fans | 41 | nos |
| Fans to be replaced with new energy efficient fans | 35 | nos |
| Monthly consumption of 35 fans | 341.25 | kWh/month |
| New monthly consumption | 147 | kWh/month |
| New monthly saving | 194.25 | kWh/month |
| New monthly saving | 2937.06 | Rs/month |
| Total Investment | 84000 | Rs |
| Payback period | 28.60 | months |

SAVING BY TARIFF CHANGE AND ELECTRICITY DUTY

OBSERVATION

- Existing tariff of girl's college is LT-3 phase residential. But applicable tariff to girl's hostel is LT-X-B-I (0-20kW) as per MSEDCL tariff order
- In electricity bill of main college, boy's hostel and girl's hostel pays electricity duty. As per Maharashtra electricity duty act-1948 and revised-2016 it is exempted.

SAVINGS MEASURES

SAVINGS DUE TO ELECTRICITY DUTY

| Particulars | | |
|---|-----------------|-----------------|
| Average monthly electricity duty of main college | 1000 | Rs/month |
| Average monthly electricity duty of boy's hostel | 5912 | Rs/month |
| Average monthly electricity duty of girl's hostel | 6081.38 | Rs/month |
| Total average electricity duty | 12993.38 | Rs/month |
| Investment | 10000 | Rs/month |
| Payback period | 0.77 | months |



SAVINGS DUE TO TARIFF CHANGE OF GIRL'S HOSTEL

| Particulars | | |
|--|----------------|-----------------|
| Existing average unit rate as per residential tariff | 15.12 | Rs/kWh |
| Average unit rate as per new tariff | 10.52 | Rs/kWh |
| Average unit rate saving | 4.6 | Rs/kWh |
| Average monthly energy consumption of girl's hostel | 2912 | kWh/month |
| Savings per month | 13395.2 | Rs/month |
| Investment | 50000 | Rs |
| Payback period | 3.73 | months |

CO₂ EMISSION REDUCTION

| Particulars | | |
|---|--------------|----------------------------------|
| Energy saved by new energy efficient technology | 165 | kWh/month |
| Energy saved by energy efficient technology | 1980 | kWh/year |
| Energy saved by renewable energy | 1125 | kWh/month |
| Energy saved by renewable energy | 13500 | kWh/year |
| CO₂ emission reduction done | 13.16 | tonnes of CO₂e |

| Particulars | | |
|--|--------------|----------------------------------|
| Energy saving potential by new energy efficient technology | 1190.08 | kWh/month |
| Energy saving potential by new energy efficient technology | 14280.96 | kWh/year |
| Energy saved by renewable energy | 1687.5 | kWh/month |
| Energy saved by renewable energy | 20250 | kWh/year |
| CO₂ emission reduction potential | 29.35 | tonnes of CO₂e |



GREEN AUDIT

EXCECUTIVE SUMMARY

| Sr no | Location | Area | Objective/Purpose | Recommendation/Status |
|-------|--|-----------------------------------|---|---|
| 1 | Boy's and Girl's hostel | Solar Water Heating System | To save conserve the energy and reduce the CO2 emission reduction by energy consumption | Implemented |
| 2 | College main building | Solar Photovoltaic System | To generate energy by renewable sources and reduce the CO2 emissions | Implemented |
| 3 | All college campus | Tree plantation/ Green belt cover | To increase the forest cover. Reduce the Air, Noise pollution, reduce CO2 emissions etc | Regularly implemented every year |
| 4 | All buildings | Tap water reducers | To save the water | Need to be implement |
| 5 | College Main building, Boy's and Girl's hostel | Window direction of the rooms | North-South direction. Reduces load of lighting, Fan during summer and sinter season. | Good |
| 6 | College main building | Waste management- Solid waste | Reduce the CO2 emissions by recycling of solid waste | Regularly implemented and maintained every month. |
| 7 | College campus | Waste management- Organic waste | Reduces the landfill pollution and green-house gases. | Implemented |
| 8 | College main building | Waste management- E-waste | Reduce the CO2 emissions by recycling of solid waste. Also Save environment from hazardous materials. | Need to be implement |

| | | | | |
|-----------|----------------|--|---|--|
| 9 | College campus | Rain water harvesting | Save water. Increases the groundwater recharge. | Implemented |
| 10 | College campus | Cleanliness drive and awareness campaign | Awareness and among the people or masses about importance cleanliness | Regularly conducting the activity by college |
| 11 | College campus | Plastic free campaign | Save environment from non recycling and hazardous materials. | Taken initiative for implementation |
| 12 | College campus | No vehicle day | Reduces the CO2 emissions | Need to be improved frequency. |

SOLAR WATER HEATING SYSTEM

OBSERVATION

1. In Boy's hostel and Girl's hostel, there are Solar Water Heating systems are installed for the purpose of water heating instead of electric heaters.
2. Total capacity of Solar Water Heating system is 1000 litres/day each.
3. No any auxiliary heaters are used in solar water heating system in the morning.



CO₂ EMISSION REDUCTION

| Particulars | | |
|--|--------------|----------------------------------|
| Hot water temperature | 60 | deg C |
| Cold water temperature | 25 | deg C |
| Temperature difference(delta T) | 35 | deg C |
| Volume of water | 2000 | lit |
| Volumetric flow | 2000 | lit/day |
| Hot water temperature | 60 | deg C |
| Enthalpy of cold water | 25.04 | kcal/kg |
| Enthalpy of Hot water | 60 | kcal/kg |
| Enthalpy difference | 34.96 | kcal/kg |
| Amount of heat used | 69920 | kcal |
| Power used for heating | 81.30 | kW |
| Monthly kWh | 2479.72 | kWh/month |
| Saving kWh | 2479.72 | kWh/month |
| Saving kWh | 29756.65 | kWh/year |
| Saving Rs | 37493.38 | Rs/month |
| CO₂ emission reduction/ year | 25.29 | tonnes of CO₂e |

SOLAR PHOTOVOLTAIC SYSTEM

OBSERVATION

1. In main college building, there is Solar Photovoltaic System is installed for the purpose of kWh units generation
2. Total capacity of Solar Photovoltaic System is 10kWp





*Solar PV system is only six month old so Performance Guarantee Test is not required.



| Particulars | | |
|-----------------------------------|-------|----------------|
| Total capacity of Solar PV system | 10 | kWp |
| Units generation per month | 1125 | kWh/month |
| Units generation per year | 13500 | kWh/year |
| CO2 emission reduction/year | 11.48 | tonnes of CO2e |

TAP WATER REDUCER

1. TAP WATER REDUCER

| Conventional Tap water system | Tap water system with Reducer |
|---|--|
|  |  |
| <p>Existing tap water system uses more water while during purpose of washing of utensils, hands etc in college.</p> | <p>Used reducer to tap water for purpose of washing of utensils, hands etc which reduces flow of water and ultimately saves the water.</p> |
|  |  |

RECOMMENDATION

It is recommended that to use water reducer for water taping for save the water.

WINDOW DIRECTION IN THE COLLEGE

Direction of Windows in the college are North and South directions



- Directions of windows in the colleges are North-South directions.
- Due to this rooms or offices get good ventilation and light/illumination.
- It saves Lighting and Fan consumption in summer and winter season considerably.

Good

TREE PLANTATION AND TREE OR FOREST COVER IN THE COLLEGE PREMISES

Tree-planting is the process of transplanting tree seedlings, generally for forestry, land reclamation, or landscaping purpose. It differs from the transplantation of larger trees in arboriculture, and from the lower cost but slower and less reliable distribution of tree seeds.

In silviculture the activity is known as reforestation, or afforestation, depending on whether the area being planted has or has not recently been forested. It involves planting seedlings over an area of land where the forest has been harvested or damaged by fire, disease or human activity. Tree planting is carried out in many different parts of the world, and strategies may differ widely across nations and regions and among individual reforestation companies.

Tree planting is grounded in forest science, and if performed properly can result in the successful regeneration of a deforested area. Reforestation is the commercial logging industry's answer to the large-scale destruction of old growth forests, but a planted forest rarely replicates the biodiversity and complexity of a natural forest. Because trees remove carbon dioxide from the air as they grow, tree planting can be used as agro engineering technique to remove CO₂ from the atmosphere. Desert greening projects are also motivated by improved biodiversity and reclamation of natural water systems, but also improved economy and social welfare due to increased number of jobs in farming and forestry.

College has planted the trees campus area to make it more environments friendly.

Tree or Forest Cover in College Campus



ACTIVITY ORGANIZED REPORT

TREE PLANTATION- 2019-20

(Academic Year: 2019-20)

| Name of activity organized | Tree Plantation |
|--------------------------------------|---|
| Title of the activity | Tree Plantation |
| Date of activity organized | 22/07/2019 |
| Place of the activity | College campus |
| No of participants (Students+ Staff) | Approximate 500 |
| Name of the sponsored organization | Yashwantrao Chavan Law College, Pune |
| Objective of the activity | To save environment, reduce CO2 emission and global warming |
| Outcome of the activity | Improve Air quality, reduces soil erosion, noise pollution |
| Trees are planted | Banyan, (Ficus benghalensis), Neem, (Azadirachta indica), Peepal Ficus religiosa, Almond (Prunus dulcis etc |
| Trees planted who maintained | College gardener and college students |

Tree Plantation Activity in the College Campus



Tree Plantation Activity in the College Campus



WASTE MANAGEMENT- E-WASTE

Electronic waste or e-waste describes discarded electrical or electronic devices. Used electronics which are destined for reuse, resale, salvage, recycling, or disposal are also considered e-waste. Informal processing of e-waste in developing countries can lead to adverse human health effects and environmental pollution.

Electronic scrap components, such as CPUs, contain potentially harmful components such as lead, cadmium, beryllium, or brominated flame retardants. Recycling and disposal of e-waste may involve significant risk to health of workers and communities in developed countries and great care must be taken to avoid unsafe exposure in recycling operations and leaking of materials such as heavy metals from landfills and incinerator ashes.

RECOMMENDATION

College need to have E-waste management policy and all the E-waste disposals generated in the college campus should be disposed/ reuse as per standard procedures/norms

The environmental impact of the processing of different electronic waste components

| E-Waste Component | Process Used | Potential Environmental Hazard |
|---|---|---|
| Cathode ray tubes (used in TVs, computer monitors, ATM, video cameras, and more) | Breaking and removal of yoke, then dumping | Lead, barium and other heavy metals leaching into the ground water and release of toxic phosphor |
| Printed circuit board (image behind table – a thin plate on which chips and other electronic components are placed) | De-soldering and removal of computer chips; open burning and acid baths to remove metals after chips are removed. | Air emissions and discharge into rivers of glass dust, tin, lead, brominated dioxin, beryllium cadmium, and mercury |
| Chips and other gold plated components | Chemical stripping using nitric and hydrochloric acid and burning of chips | PAHs, heavy metals, brominated flame retardants discharged directly into rivers acidifying fish and flora. Tin and lead contamination of surface and groundwater. Air emissions of brominated dioxins, heavy metals, and PAHs |
| Plastics from printers, keyboards, monitors, etc. | Shredding and low temp melting to be reused | Emissions of brominated dioxins, heavy metals, and hydrocarbons |
| Computer wires | Open burning and stripping to remove copper | PAHs released into air, water, and soil. |

WASTE MANAGEMENT- SOLID WASTE

College have good policy and maintained the record for solid waste generated in the college like old newspapers, books, scrap boxes, etc.

Record of the Solid Waste Management

प्रो.प्रा. रवि सावंत

॥ श्री पांजरनाथ प्रसन्न ॥ मो.नं. 9096094327
॥ श्री गजानन प्रसन्न ॥ 9890401354

आदित्य एन्टरप्रायजेस
शासकीय रद्दी कागदाचे खरेदीदार व पेपर मिल सप्लायर्स
सर्व्हे नं. १३, डबरी नगर, सावंत चाळ, सोलापूर रोड, टेकवडे पेट्रोल पंपामागे, आकाशवाणी, हडपसर, पुणे-२८

जावक नं. दिनांक १२/१२/२० १९

प्रति, आदित्य एन्टरप्रायजेस
२४/११/१९ जुलै ०१
महाराष्ट्र ४००

Aditya Enterprises
Sr.No. 13, Akashwani, Sholapur Road,
Hadapsar, Pune-411 028.
Cell : 9096094327

विषय : जुने रद्दी कागद खरेदीबाबत

मा. महोदय,
वरील विषयास अनुसरून विनंती की, आम्ही रद्दी कागदाचे अधिकृत खरेदीदार आहोत. आम्ही राष्ट्रीयकृत बँकांची, शासकीय, निमशासकीय कार्यालयातील तसेच विद्यालय व महाविद्यालयातील जुने रद्दी कागद खरेदी करतो ते रद्दी कागद पेपर मिलला लगदा (पल्प) करण्यासाठी पाठवतो. त्या रद्दी कागदाचा बाहेर कुठेही दुरुपयोग केला जाणार नाही. तसेच पेपर मिलचे प्रमाणपत्र आम्ही आपणास सादर करू. आमचे रद्दी कागद खरेदी करण्याचे दर खालील प्रमाणे देत आहोत.

रद्दी दर (प्रती १ किलो प्रमाणे)

| अ. नं. | रद्दीचे प्रकार | दर | रुपये | पैसे |
|--------|-------------------------|----|-------|------|
| १) | जुने मोठी उत्तर पत्रिका | २ | २२ | २३० |
| २) | जुने लहान उत्तर पत्रिका | १ | ११ | २६५ |
| ३) | जुने वर्तमान पत्र | १ | १० | २६० |
| ४) | जुने मासिक व पुस्तके | १ | ९ | २३० |
| ५) | जुने फाईल रद्दी | २ | १६ | २२० |
| ६) | जुने वहाणांची रद्दी | १ | ५ | २५० |
| ७) | लुज कागद रद्दी | १ | २१ | २०० |
| ८) | जुने लोखंडी भंगार | १ | ३ | २५० |
| ९) | किरकोळ | १ | | |

PRINCIPAL
Yashwantrao Chavan Law College
Pune - 411 009.

आपला नम्र : आदित्य एन्टरप्रायजेस
प्रो.प्रा. रवि सावंत

टीप : वरील रद्दी कागद आम्हास मिळावे हि विनंती

- College have taken good initiative for solid waste management in the college.
- College given the solid waste generated in the college to the authorised third party viz. Aditya Enterprises periodically.
- So Solid waste in the college is managed properly through authorised channel for recycling it.

WASTE MANAGEMENT- ORGNAIC WASTE

In the college there college Canteen, Boy's and Girl's hostel and Trees which are mainly generated wet and dry solid waste.

Record of the Solid Waste Management



- College have main centralised facility in the premises where wet and dry waste generated is collected.
- Collected waste is further processed internally and makes the organic waste instead of landfill. Generated organic compost is used for garden trees.
- College has already implemented the self processed internally organic waste management system.

RAIN WATER HARVESTING

There is a good potential for rain water harvesting in a college. This water can be used for purposes like gardening, bores, wells, etc.

Rain Water Harvesting Well in the College



- College have taken good initiative at campus level for rain water harvesting.
- College have centralised rain water harvesting well where all rain water is collected.
- Rain water is by gravity is comes to the well by piping made at various location in college premises.

CLEANLINESS DRIVE AND AWARENESS CAMPAIGN

ACTIVITY ORGANIZED REPORT

CLEANLINESS DRIVE AND AWARENESS CAMPAIGN- 2019-20

(Academic Year: 2019-20)

| | |
|---|---|
| Name of activity organized | Cleanliness Drive and Awareness Campaign |
| Title of the activity | Cleanliness Drive and Awareness campaign |
| Date of activity organized | 19/09/2019 25/09/2019 |
| Place of the activity | College campus, Aryaneshwar Area in Pune |
| No of participants (Students+ Staff) | 140 |
| Participants | NSS students and Other college students and Staff etc |
| Name of the sponsored organization | Yashwantrao Chavan Law College, Pune |
| Objective of the activity | <ul style="list-style-type: none"> - Removal of plastic debris. - The plastic debris is responsible for the environmental harm. - As the plastic does not decompose or dissolve and poses serious harm to health - Clean the area in Aryaneshwar which is hampered due to heavy rain fall and flood in the month of September-2019 - To aware the people about the diseases created due to unclean area like Malaria, Dengue etc |
| Outcome of the activity | <ul style="list-style-type: none"> - To aware the people about importance of cleanliness. - To save the environment from hazardous materials like plastic debris this is not easily decomposed. |

Cleanliness Drive and Awareness Campaign



Cleanliness Drive and Awareness Campaign



PLASTIC FREE CAMPUS CAMPAIGN

College have taken initiative for single used plastic free in the campus. As single used plastic is hazardous to the environment as it is once used cannot be recycled. So it is good initiative taken by college in 2019-20 year under the guidance of college principal.

ACTIVITY ORGANIZED REPORT

SINGLE USED PLASTIC FREE - 2019-20

(Academic Year: 2019-20)

| Name of activity organized | Single used plastic Campaign |
|--------------------------------------|---|
| Title of the activity | Single used plastic Campaign |
| Date of activity organized | 01/11/2019 |
| Place of the activity | College campus |
| Guide | Principal- Ms Dr Shubhada Gholap Madam |
| No of participants (Students+ Staff) | All students and staff |
| Name of the sponsored organization | Yashwantrao Chavan Law College, Pune |
| Objective of the activity | - Single used plastic is hazardous to the environment as it is once used cannot be recycled |

Single used plastic Campaign



NO VEHICLE DAY

Many of the college students and staff use the private or own vehicle to come college. It contributes the CO₂ emission due to burning of petrol or diesel in the vehicles.

RECOMMENDATION

It is recommended to follow 1 day per month no vehicle day in the college campus. Instead of that use the public transport to reduce the CO₂ emission.

ANNEXTURE

TOTAL SAVING- MAIN COLLEGE

| Particulars | | |
|---------------------------|---------------|-----------------|
| Monthly consumption | 658.72 | kWh/month |
| New monthly consumption | 263.19 | kWh/month |
| New monthly saving | 340.71 | kWh/month |
| New monthly saving | 3407.1 | Rs/month |
| Total Investment | 139200 | Rs |
| Payback period | 40.86 | months |

TOTAL SAVING- BOY'S HOSTEL

| Particulars | | |
|---------------------------|----------------|-----------------|
| Monthly consumption | 996 | kWh/month |
| New monthly consumption | 492.9 | kWh/month |
| New monthly saving | 503.1 | kWh/month |
| New monthly saving | 5292.61 | Rs/month |
| Total Investment | 188100 | Rs |
| Payback period | 35.54 | months |

TOTAL SAVING- GIRL'S HOSTEL

| Particulars | | |
|---------------------------|----------------|-----------------|
| Monthly consumption | 642.8 | kWh/month |
| New monthly consumption | 296.53 | kWh/month |
| New monthly saving | 346.27 | kWh/month |
| New monthly saving | 5235.60 | Rs/month |
| Total Investment | 102600 | Rs |
| Payback period | 19.60 | months |